



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

August 22, 2016

Doug Pigman
Greater Albany Public Schools
3610 Grand Prairie
Albany, OR 97322
TEL: (541) 967-4513
FAX

RE: Calapooia

Order No.: 1607C33

Dear Doug Pigman:

Analytical Laboratory Group received 36 sample(s) on 7/26/2016 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reever Morghan'.

Kimberly Reever Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 1607C33

Date: 8/22/2016

CLIENT: Greater Albany Public Schools

Project: Calapooia

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

WO#: 1607C33
CLIENT: Greater Albany Public Schools
Project: Calapooia
PWS Number:
Sample Source:

Received Date: 7/26/2016 2:20:00 PM
Sampler Name: Stephanie Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID			Collection Date:			
1607C33-001	Rm 1 Sink			7/18/2016 2:53:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	0.00220	0.0200	0.00200	mg/L	8/20/2016 7:29:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607C33-002	First Aid Rm Sink			7/18/2016 2:56:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	8/20/2016 7:29:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607C33-003	Office Sink			7/18/2016 2:56:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	0.00241	0.0200	0.00200	mg/L	8/20/2016 7:29:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607C33-004	North Hall Tall Fntn			7/18/2016 2:52:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	8/20/2016 7:29:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607C33-005	North Hall Short Fntn			7/18/2016 2:52:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	8/20/2016 7:29:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607C33-006	Rm 5 Sink			7/18/2016 2:56:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	8/20/2016 7:29:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607C33-007	Cafeteria Fntn			7/18/2016 2:55:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	8/20/2016 7:29:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607C33-008	Band Room Fntn			7/18/2016 2:56:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	8/20/2016 7:29:00 PM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607C33
CLIENT: Greater Albany Public Schools
Project: Calapooia
PWS Number:
Sample Source:

Received Date: 7/26/2016 2:20:00 PM
Sampler Name: Stephanie Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1607C33-009 **Client Sample ID:** Staff Rm Sink **Collection Date:** 7/18/2016 2:58:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/20/2016 7:29:00 PM	PG
------	-----------	----	--------	---------	--	------	----------------------	----

Lab ID: 1607C33-010 **Client Sample ID:** Dishwashing Sink E **Collection Date:** 7/18/2016 2:55:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/20/2016 7:29:00 PM	PG
------	-----------	----	--------	---------	--	------	----------------------	----

Lab ID: 1607C33-011 **Client Sample ID:** Rm 26 Sink A **Collection Date:** 7/18/2016 3:00:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/20/2016 7:29:00 PM	PG
------	-----------	----	--------	---------	--	------	----------------------	----

Lab ID: 1607C33-012 **Client Sample ID:** Rm 26 Sink B **Collection Date:** 7/18/2016 3:00:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00619	0.0200	0.00200		mg/L	8/20/2016 7:29:00 PM	PG
------	-----------	---------	--------	---------	--	------	----------------------	----

Lab ID: 1607C33-013 **Client Sample ID:** Rm 26 Sink C **Collection Date:** 7/18/2016 3:01:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00227	0.0200	0.00200		mg/L	8/20/2016 7:29:00 PM	PG
------	-----------	---------	--------	---------	--	------	----------------------	----

Lab ID: 1607C33-014 **Client Sample ID:** Rm 26 Sink D **Collection Date:** 7/18/2016 3:01:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00714	0.0200	0.00200		mg/L	8/20/2016 7:29:00 PM	PG
------	-----------	---------	--------	---------	--	------	----------------------	----

Lab ID: 1607C33-015 **Client Sample ID:** Rm 26 Sink E **Collection Date:** 7/18/2016 3:02:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00539	0.0200	0.00200		mg/L	8/20/2016 7:29:00 PM	PG
------	-----------	---------	--------	---------	--	------	----------------------	----

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607C33
CLIENT: Greater Albany Public Schools
Project: Calapooia
PWS Number:
Sample Source:

Received Date: 7/26/2016 2:20:00 PM
Sampler Name: Stephanie Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00815	0.0200	0.00200		mg/L	8/20/2016 7:29:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00555	0.0200	0.00200		mg/L	8/20/2016 7:29:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/20/2016 7:29:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/20/2016 7:29:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00207	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00364	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607C33
CLIENT: Greater Albany Public Schools
Project: Calapooia
PWS Number:
Sample Source:

Received Date: 7/26/2016 2:20:00 PM
Sampler Name: Stephanie Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1607C33-024 **Client Sample ID:** East Fntn **Collection Date:** 7/18/2016 2:57:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Lab ID: 1607C33-025 **Client Sample ID:** Rm 25 Sink **Collection Date:** 7/18/2016 3:00:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Lab ID: 1607C33-026 **Client Sample ID:** Rm 17 Sink **Collection Date:** 7/18/2016 3:01:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00242	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Lab ID: 1607C33-027 **Client Sample ID:** Rm 27 Sink **Collection Date:** 7/18/2016 3:02:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Lab ID: 1607C33-028 **Client Sample ID:** Rm 28 Sink **Collection Date:** 7/18/2016 3:03:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Lab ID: 1607C33-029 **Client Sample ID:** South Hall Short Fntn **Collection Date:** 7/18/2016 3:06:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Lab ID: 1607C33-030 **Client Sample ID:** South Hall Tall Fntn **Collection Date:** 7/18/2016 3:06:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 1607C33
CLIENT: Greater Albany Public Schools
Project: Calapooia
PWS Number:
Sample Source:

Received Date: 7/26/2016 2:20:00 PM
Sampler Name: Stephanie Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	Small Gym Fntn	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Lab ID:	Client Sample ID	Big Gym Fntn	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Lab ID:	Client Sample ID	Girls LR Fntn	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Lab ID:	Client Sample ID	Boys LR Fntn	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/21/2016 6:57:00 AM	KG

Lab ID:	Client Sample ID	Shop Fntn	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.148	0.0200	0.0200	*	mg/L	7/30/2016 7:15:00 AM	KG

Lab ID:	Client Sample ID	Shop Classroom Sink	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0315	0.0200	0.00400	*	mg/L	8/21/2016 6:57:00 AM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1607C33
 22-Aug-16

Client: Greater Albany Public Schools
Project: Calapooia

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607C33-001A	Rm 1 Sink	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607C33-002A	First Aid Rm Sink			Lead	A
	1607C33-003A	Office Sink			Lead	A
	1607C33-004A	North Hall Tall Fntn			Lead	A
	1607C33-005A	North Hall Short Fntn			Lead	A
	1607C33-006A	Rm 5 Sink			Lead	A
	1607C33-007A	Cafeteria Fntn			Lead	A
	1607C33-008A	Band Room Fntn			Lead	A
	1607C33-009A	Staff Rm Sink			Lead	A
	1607C33-010A	Dishwashing Sink E			Lead	A
	1607C33-011A	Rm 26 Sink A			Lead	A
	1607C33-012A	Rm 26 Sink B			Lead	A
	1607C33-013A	Rm 26 Sink C			Lead	A
	1607C33-014A	Rm 26 Sink D			Lead	A
	1607C33-015A	Rm 26 Sink E			Lead	A
	1607C33-016A	Rm 26 Sink F			Lead	A
	1607C33-017A	Rm 26 Sink G			Lead	A
	1607C33-018A	Rm 29 Sink			Lead	A
	1607C33-019A	Rm 30 Sink			Lead	A
	1607C33-020A	West Hall Fntn			Lead	A
	1607C33-021A	Pot Sink			Lead	A
	1607C33-022A	Handwashing Sink			Lead	A
	1607C33-023A	Dishwashing Sink W			Lead	A
	1607C33-024A	East Fntn			Lead	A
	1607C33-025A	Rm 25 Sink			Lead	A
	1607C33-026A	Rm 17 Sink			Lead	A
	1607C33-027A	Rm 27 Sink			Lead	A
	1607C33-028A	Rm 28 Sink			Lead	A
	1607C33-029A	South Hall Short Fntn			Lead	A
	1607C33-030A	South Hall Tall Fntn			Lead	A

ORELAP A Accredited

ACCRED

Original #1607C33# v1



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1607C33
 22-Aug-16

Client: Greater Albany Public Schools
Project: Calapooia

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607C33-031A	Small Gym Fntn	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607C33-032A	Big Gym Fntn			Lead	A
	1607C33-033A	Girls LR Fntn			Lead	A
	1607C33-034A	Boys LR Fntn			Lead	A
	1607C33-035A	Shop Fntn			Lead	A
	1607C33-036A	Shop Classroom Sink			Lead	A

ORELAP A Accredited

ACCRED



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1607C33

Date: 8/22/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Definition Base

WO#: 1607C33
Date: 8/22/2016

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- A Accredited by ORELAP
- C Value is below Minimum Compound Limit.
- E Value above quantitation range
- H Holding times for preparation or analysis exceeded
- LOD Limit of Detection
- MCL Maximum Contaminant Level
- NAR See note in Case Narrative
- ND Not Detected at the Reporting Limit
- PL Permit Limit
- R RPD outside accepted recovery limits
- RL Reporting Detection Limit
- U Samples with CalcVal < MDL
- W Sample container temperature is out of limit as specified at testcode

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering in
just test res.

NPUC

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@albanymk2.or.us</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Calapooia</u>	Sampler: Print <u>Stephanie Dilbone</u> Sampler: Signature <u>Stephanie Dilbone</u>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 1 sink	DW/Grab	7-18	2:53	Lead	P	1			001A
First aid Rm sink	DW/Grab	7-18	2:56	Lead	P	1			002A
Office sink	DW/Grab	7-18	2:56	Lead	P	1			003A
North hall tall fount	DW/Grab	7-18	2:52	Lead	P	1			004A
North hall short fount	DW/Grab	7-18	2:52	Lead	P	1			005A
Rm 5 sink	DW/Grab	7-18	2:56	Lead	P	1			006A
cafeteria fount.	DW/Grab	7-18	2:55	Lead	P	1			007A
Band room fount	DW/Grab	7-18	2:56	Lead	P	1			008A
Staff Rm sink	DW/Grab	7-18	2:58	Lead	P	1			009A
dishwashing sink	DW/Grab	7-8	2:55	Lead	P	1			010A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG Courier</u>	Refrigerated: <u>NA</u>	
Relinquished by:	Date Time	Received by:	Date Time
Relinquished by:	Date Time	Received by:	Date Time
Relinquished by:	Date Time	Received by Laboratory:	Date Time
<u>MF</u>	<u>7/26/16</u> <u>1420</u>	<u>[Signature]</u>	<u>7/26/16</u> <u>1420</u>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering just test

NPUC

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@albanymk2.or.us</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Calapooia</u>	Sampler: Print <u>Stephanie Dillbone</u> Sampler: Signature <u>Stephanie Dillbone</u>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 26 sink A	DW/Grab	7-18	3:00	Lead	P	1			011A
Rm 26 sink B	DW/Grab	7-18	3:00	Lead	P	1			012A
Rm 26 sink C	DW/Grab	7-18	3:01	Lead	P	1			013A
Rm 26 sink D	DW/Grab	7-18	3:01	Lead	P	1			014A
Rm 26 sink E	DW/Grab	7-18	3:02	Lead	P	1			015A
Rm 26 sink F	DW/Grab	7-18	3:02	Lead	P	1			016A
Rm 26 sink G	DW/Grab	7-18	3:03	Lead	P	1			017A
Rm 29 sink	DW/Grab	7-18	3:19	Lead	P	1			018A
Rm 30 sink	DW/Grab	7-18	3:18	Lead	P	1			019A
West hall fountain	DW/Grab	7-18	3:06	Lead	P	1			020A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG Courier</u>	Refrigerated: <u>NA</u>	
Relinquished by:	Date Time	Received by:	Date Time
Relinquished by:	Date Time	Received by:	Date Time
Relinquished by:	Date Time	Received by Laboratory:	Date Time
<u>MF</u>	<u>7/26/16</u> <u>1420</u>	<u>[Signature]</u>	<u>7/26/16</u> <u>1420</u>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering more than
just test results

CHAIN OF CUSTODY

NPUC

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@alglabsinc.com</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Calapooia</u>	Sampler: Print <u>Stephanie Dilbone</u> Sampler: Signature <u>Stephanie Dilbone</u>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Pot sink	DW/Grab	7-18	2:55	Lead	P	1			021A
handwashing sink	DW/Grab	7-18	2:55	Lead	P	1			022A
dishwashing sink w	DW/Grab	7-18	2:55	Lead	P	1			023A
East fountain	DW/Grab	7-18	2:57	Lead	P	1			024A
Rm 25 sink	DW/Grab	7-18	3:00	Lead	P	1			025A
Rm 26 sink	DW/Grab	7-18		Lead	P	1			
Rm 17 sink	DW/Grab	7-18	3:01	Lead	P	1			026A
Rm 27 sink	DW/Grab	7-18	3:02	Lead	P	1			027A
Rm 28 fount	DW/Grab	7-18	3:03	Lead	P	1			
Rm 28 sink	DW/Grab	7-18	3:03	Lead	P	1			028A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG Courier</u>	Refrigerated: <u>NA</u>
---	---------------------------------	-------------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
			<u>MF</u>	<u>7/26/16</u>	<u>1330</u>
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>MF</u>	<u>7/26/16</u>	<u>1420</u>	<u>[Signature]</u>	<u>7/26/16</u>	<u>1420</u>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

NPUC

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@albanymk2.oeus.k12.or.us</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Calapooia</u>	Sampler: Print <u>Stephanie Dilbone</u> Sampler: Signature <u>Stephanie Dilbone</u>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
<u>South hall short fount</u>	<u>DW/Grab</u>	<u>7-18</u>	<u>3:06</u>	<u>Lead</u>	<u>P</u>	<u>1</u>			<u>029A</u>
<u>South hall tall fount</u>	<u>DW/Grab</u>	<u>7-18</u>	<u>3:06</u>	<u>Lead</u>	<u>P</u>	<u>1</u>			<u>030A</u>
<u>small gym fount</u>	<u>DW/Grab</u>	<u>7-18</u>	<u>3:02</u>	<u>Lead</u>	<u>P</u>	<u>1</u>			<u>031A</u>
<u>Big gym fount</u>	<u>DW/Grab</u>	<u>7-18</u>	<u>3:05</u>	<u>Lead</u>	<u>P</u>	<u>1</u>			<u>032A</u>
<u>Girls locker rm fount</u>	<u>DW/Grab</u>	<u>7-18</u>	<u>3:03</u>	<u>Lead</u>	<u>P</u>	<u>1</u>			<u>033A</u>
<u>Boys locker Rm fount</u>	<u>DW/Grab</u>	<u>7-18</u>	<u>3:04</u>	<u>Lead</u>	<u>P</u>	<u>1</u>			<u>034A</u>
<u>Shop fountain</u>	<u>DW/Grab</u>	<u>7-18</u>	<u>3:07</u>	<u>Lead</u>	<u>P</u>	<u>1</u>			<u>035A</u>
<u>Shop classroom sink</u>	<u>DW/Grab</u>	<u>7-18</u>	<u>3:07</u>	<u>Lead</u>	<u>P</u>	<u>1</u>			<u>036A</u>
	<u>DW/Grab</u>	<u>7-18</u>		<u>Lead</u>	<u>P</u>	<u>1</u>			
	<u>DW/Grab</u>	<u>7-18</u>		<u>Lead</u>	<u>P</u>	<u>1</u>			

Notes:	<table border="1" style="width:100%"> <thead> <tr> <th colspan="5">Preservation Check</th> </tr> <tr> <th>Lab ID</th> <th>Date/Time</th> <th>Pre-Preserved</th> <th>pH</th> <th>Tech</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	Preservation Check					Lab ID	Date/Time	Pre-Preserved	pH	Tech																																													
Preservation Check																																																								
Lab ID	Date/Time	Pre-Preserved	pH	Tech																																																				

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: <u>ALG Courier</u>	Refrigerated <u>NA</u>			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
			<u>MF</u>	<u>7/26/16</u>	<u>1330</u>
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>MF</u>	<u>7/26/16</u>	<u>1420</u>	<u>[Signature]</u>	<u>7/26/16</u>	<u>1420</u>