



ALG ORELAP ID #OR100012  
361 West 5th Ave  
Eugene, OR 97401  
TEL: (541) 485-8404 FAX: (541) 484-5995  
Website:

September 19, 2016

Doug Pigman  
Greater Albany Public Schools  
3610 Grand Prairie  
Albany, OR 97322  
TEL: (541) 967-4513  
FAX

RE: Rushed Samples

Order No.: 1609582

Dear Doug Pigman:

Analytical Laboratory Group received 29 sample(s) on 9/13/2016 for the analyses presented in the following report.

Kimberly Reeve Morghan  
Quality Manager  
361 West 5th Ave  
Eugene, OR 97401



*Delivering more than  
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

## Case Narrative

WO#: **1609582**

Date: **9/19/2016**

---

**CLIENT:** Greater Albany Public Schools

**Project:** Rushed Samples

---

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

**WO#:** 1609582  
**CLIENT:** Greater Albany Public Schools  
**Project:** Rushed Samples  
**PWS Number:**  
**Sample Source:**

**Received Date:** 9/13/2016 4:01:00 PM  
**Sampler Name:** Jessica Dilbone  
**Matrix:** Drinking Water  
**Sample Type:**

**Lab ID:** 1609582-001      **Client Sample ID:** District Office Staff Rm Faucet 2      **Collection Date:** 9/12/2016 2:39:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/16/2016 2:06:00 PM	KG

**Lab ID:** 1609582-002      **Client Sample ID:** Lafayette Rm 3 Faucet      **Collection Date:** 9/12/2016 7:38:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00367	0.0200	0.00200		mg/L	9/16/2016 2:06:00 PM	KG

**Lab ID:** 1609582-003      **Client Sample ID:** Lafayette Rm 3 SDF      **Collection Date:** 9/12/2016 7:38:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00289	0.0200	0.00200		mg/L	9/16/2016 2:06:00 PM	KG

**Lab ID:** 1609582-004      **Client Sample ID:** Lafayette Rm 9 Faucet      **Collection Date:** 9/12/2016 7:39:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0336	0.0200	0.00400	*	mg/L	9/16/2016 2:06:00 PM	KG

**Lab ID:** 1609582-005      **Client Sample ID:** Lafayette Rm 18 Faucet      **Collection Date:** 9/12/2016 7:40:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0104	0.0200	0.00200		mg/L	9/16/2016 2:06:00 PM	KG

**Lab ID:** 1609582-006      **Client Sample ID:** Liberty Rm 7 Faucet      **Collection Date:** 9/12/2016 3:07:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/16/2016 2:06:00 PM	KG

**Lab ID:** 1609582-007      **Client Sample ID:** Liberty Rm 8 Faucet      **Collection Date:** 9/12/2016 3:09:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/16/2016 2:06:00 PM	KG

**Lab ID:** 1609582-008      **Client Sample ID:** Liberty Rm 18 Faucet      **Collection Date:** 9/12/2016 3:12:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0150	0.0200	0.00200		mg/L	9/16/2016 2:06:00 PM	KG

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012  
 361 West 5th Ave  
 Eugene, OR 97401  
 TEL: (541) 485-8404 FAX: (541) 484-5995  
 Website:

# Analytical Report

Date Reported 9/19/2016

**WO#:** 1609582  
**CLIENT:** Greater Albany Public Schools  
**Project:** Rushed Samples  
**PWS Number:**  
**Sample Source:**

**Received Date:** 9/13/2016 4:01:00 PM  
**Sampler Name:** Jessica Dilbone  
**Matrix:** Drinking Water  
**Sample Type:**

**Lab ID:** 1609582-009      **Client Sample ID:** Liberty Rm 19 Faucet      **Collection Date:** 9/12/2016 3:13:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00871	0.0200	0.00200		mg/L	9/16/2016 2:06:00 PM	KG

**Lab ID:** 1609582-010      **Client Sample ID:** Memorial Kitchen Faucet      **Collection Date:** 9/12/2016 2:18:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/16/2016 2:06:00 PM	KG

**Lab ID:** 1609582-011      **Client Sample ID:** Memorial B1/B3 Mid Rm Faucet      **Collection Date:** 9/12/2016 2:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-012      **Client Sample ID:** Memorial East BHall Left Fntn      **Collection Date:** 9/12/2016 2:21:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-013      **Client Sample ID:** Memorial East BHall Right Fntn      **Collection Date:** 9/12/2016 2:21:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-014      **Client Sample ID:** South Albany Gym Left Fntn      **Collection Date:** 9/12/2016 7:28:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-015      **Client Sample ID:** South Albany Gym Right Fntn      **Collection Date:** 9/12/2016 7:28:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

**WO#:** 1609582  
**CLIENT:** Greater Albany Public Schools  
**Project:** Rushed Samples  
**PWS Number:**  
**Sample Source:**

**Received Date:** 9/13/2016 4:01:00 PM  
**Sampler Name:** Jessica Dilbone  
**Matrix:** Drinking Water  
**Sample Type:**

**Lab ID:** 1609582-016      **Client Sample ID** South Shore Special Ed Faucet      **Collection Date:** 9/12/2016 5:07:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00242	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-017      **Client Sample ID** Calapooia Kitchen Faucet 1      **Collection Date:** 9/12/2016 6:11:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-018      **Client Sample ID** Calapooia Kitchen Faucet 2      **Collection Date:** 9/12/2016 6:11:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-019      **Client Sample ID** Calapooia Kitchen Faucet 3      **Collection Date:** 9/12/2016 6:12:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00863	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-020      **Client Sample ID** Calapooia Kitchen Faucet 4      **Collection Date:** 9/12/2016 6:12:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00312	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-021      **Client Sample ID** Fir Grove Library South Faucet      **Collection Date:** 9/12/2016 3:21:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-022      **Client Sample ID** Sunrise Resource Rm Faucet      **Collection Date:** 9/12/2016 5:26:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00527	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-023      **Client Sample ID** Sunrise Rm 13 Faucet      **Collection Date:** 9/12/2016 5:28:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0143	0.0200	0.00200		mg/L	9/16/2016 2:06:00 PM	KG

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

**WO#:** 1609582  
**CLIENT:** Greater Albany Public Schools  
**Project:** Rushed Samples  
**PWS Number:**  
**Sample Source:**

**Received Date:** 9/13/2016 4:01:00 PM  
**Sampler Name:** Jessica Dilbone  
**Matrix:** Drinking Water  
**Sample Type:**

**Lab ID:** 1609582-024      **Client Sample ID:** Sunrise Rm 10 Faucet      **Collection Date:** 9/12/2016 5:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00289	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-025      **Client Sample ID:** Sunrise Rm 1 Fntn      **Collection Date:** 9/12/2016 5:32:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0220	0.0200	0.00400	*	mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-026      **Client Sample ID:** Sunrise Rm 2 Faucet      **Collection Date:** 9/12/2016 5:33:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0129	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-027      **Client Sample ID:** Tangent Rm 3 SDF      **Collection Date:** 9/12/2016 12:43:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00399	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-028      **Client Sample ID:** Tangent Rm 5 SDF      **Collection Date:** 9/12/2016 12:45:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00796	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Lab ID:** 1609582-029      **Client Sample ID:** Tangent Rm 11 Faucet      **Collection Date:** 9/12/2016 12:48:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0192	0.0200	0.00200		mg/L	9/17/2016 8:12:00 AM	PG

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012  
 361 West 5th Ave  
 Eugene, OR 97401  
 TEL: (541) 485-8404 FAX: (541) 484-5995  
 Website:

## Accreditation Program Analytes Report

WO#: 1609582  
 19-Sep-16

**Client:** Greater Albany Public Schools  
**Project:** Rushed Samples

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1609582-001A	District Office Staff Rm Faucet 2	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1609582-002A	Lafayette Rm 3 Faucet			Lead	A
	1609582-003A	Lafayette Rm 3 SDF			Lead	A
	1609582-004A	Lafayette Rm 9 Faucet			Lead	A
	1609582-005A	Lafayette Rm 18 Faucet			Lead	A
	1609582-006A	Liberty Rm 7 Faucet			Lead	A
	1609582-007A	Liberty Rm 8 Faucet			Lead	A
	1609582-008A	Liberty Rm 18 Faucet			Lead	A
	1609582-009A	Liberty Rm 19 Faucet			Lead	A
	1609582-010A	Memorial Kitchen Faucet			Lead	A
	1609582-011A	Memorial B1/B3 Mid Rm Faucet			Lead	A
	1609582-012A	Memorial East BHall Left Fntn			Lead	A
	1609582-013A	Memorial East BHall Right Fntn			Lead	A
	1609582-014A	South Albany Gym Left Fntn			Lead	A
	1609582-015A	South Albany Gym Right Fntn			Lead	A
	1609582-016A	South Shore Special Ed Faucet			Lead	A
	1609582-017A	Calapooia Kitchen Faucet 1			Lead	A
	1609582-018A	Calapooia Kitchen Faucet 2			Lead	A
	1609582-019A	Calapooia Kitchen Faucet 3			Lead	A
	1609582-020A	Calapooia Kitchen Faucet 4			Lead	A
	1609582-021A	Fir Grove Library South Faucet			Lead	A
	1609582-022A	Sunrise Resource Rm Faucet			Lead	A

ORELAP A Accredited

ACCRED

Original #1609582# v1



ALG ORELAP ID #OR100012  
 361 West 5th Ave  
 Eugene, OR 97401  
 TEL: (541) 485-8404 FAX: (541) 484-5995  
 Website:

## Accreditation Program Analytes Report

WO#: 1609582  
 19-Sep-16

**Client:** Greater Albany Public Schools  
**Project:** Rushed Samples

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1609582-023A	Sunrise Rm 13 Faucet	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1609582-024A	Sunrise Rm 10 Faucet			Lead	A
	1609582-025A	Sunrise Rm 1 Fntn			Lead	A
	1609582-026A	Sunrise Rm 2			Lead	A
	1609582-027A	Tangent Rm 3 SDF			Lead	A
	1609582-028A	Tangent Rm 5 SDF			Lead	A
	1609582-029A	Tangent Rm 11 Faucet			Lead	A

ORELAP A Accredited

ACCRED





Delivering more than  
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

## Definition Base

WO#: 1609582

Date: 9/19/2016

---

### Definitions:

**% REC:** Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

**% RPD:** Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

**DF:** Dilution factor; the dilution factor applied to the prepared sample.

**DUP:** Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

**LCS:** Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

**LCSD:** The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

**MBLK:** Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

**MS:** Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

**MSD:** The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

**ND:** Not Detected. The analyte level is below the lowest point the laboratory can test for.

**PL:** Permit limit; only applicable to wastewater reports.

**PQL:** Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

**Qual:** Qualifier that applies to the analyte reported

---

Original

Page 9 of 10

## Definition Base

WO#: 1609582  
Date: 9/19/2016

---

### Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

### Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
 EUGENE, OREGON 97401  
 800-262-5973/541-485-8404 Fax 541-484-5995  
 Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



Delivering just test results

NPUC

## CHAIN OF CUSTODY

<b>Attention:</b> Doug Pigman	<b>Client:</b> Greater Albany Public Schools
<b>Phone:</b> 541-967-4513	<b>Address:</b> 3610 Grand Prairie
<b>Email:</b> doug.pigman@albany.k12.or.us	<b>City, State, Zip:</b> Albany, OR 97322
<b>Client Project:</b> Rushed Samples	<b>Sampler:</b> Print Jessica Dilbone
	<b>Sampler:</b> Signature Jessica Dilbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
District Office Staff Rm Faucet 2	DW/Grab	9-12-16	2:39a	Lead	P	1			001A
Lafayette Rm 3 Faucet	DW/Grab	9-12-16	7:38a	Lead	P	1			002A
Lafayette Rm 3 SDF	DW/Grab	9-12-16	7:38a	Lead	P	1			003A
Lafayette Rm 9 Faucet	DW/Grab	9-12-16	7:39a	Lead	P	1			004A
Lafayette Rm 18 Faucet	DW/Grab	9-12-16	7:40a	Lead	P	1			005A
Liberty Rm 7 Faucet	DW/Grab	9-9-16	3:07p	Lead	P	1			006A
Liberty Rm 8 Faucet	DW/Grab	9-9-16	3:09p	Lead	P	1			007A
Liberty Rm 18 Faucet	DW/Grab	9-9-16	3:12p	Lead	P	1			008A
Liberty Rm 19 Faucet	DW/Grab	9-9-16	3:13p	Lead	P	1			009A
Memorial Kitchen Faucet	DW/Grab	9-12-16	2:18a	Lead	P	1			010A

**Notes:**

---



---



---



---



---



---



---



---

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

<b>Turn Around Time Requested (Rush incurs a Surcharge):</b> <input type="checkbox"/> NORMAL <input checked="" type="checkbox"/> RUSH	<b>Shipped Via:</b> ALG Courier	<b>Refrigerated:</b> NA
--	------------------------------------	----------------------------

<b>Relinquished by:</b> Jessica Dilbone	<b>Date</b> 9-13-16	<b>Time</b> 1358	<b>Received by:</b> <i>[Signature]</i>	<b>Date</b> 9/13/16	<b>Time</b> 1358
<b>Relinquished by:</b>	<b>Date</b>	<b>Time</b>	<b>Received by:</b> <i>[Signature]</i>	<b>Date</b> 9/13/16	<b>Time</b> 1601
<b>Relinquished by:</b> <i>[Signature]</i>	<b>Date</b> 9/13/16	<b>Time</b> 1601	<b>Received by Laboratory:</b> <i>[Signature]</i>	<b>Date</b> 9/13/16	<b>Time</b> 1601

# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
 EUGENE, OREGON 97401  
 800-262-5973/541-485-8404 Fax 541-484-5995  
 Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



*Delivery more than just test result*

## CHAIN OF CUSTODY

NPUC

<b>Attention:</b> Doug Pigman	<b>Client:</b> Greater Albany Public Schools
<b>Phone:</b> 541-967-4513	<b>Address:</b> 3610 Grand Prairie
<b>Email:</b> <a href="mailto:doug.pigman@albany.k12.or.us">doug.pigman@albany.k12.or.us</a>	<b>City, State, Zip:</b> Albany, OR 97322
<b>Client Project:</b> Rushed Samples	<b>Sampler:</b> Print Jessica Dilbone
	<b>Sampler:</b> Signature Jessica Dilbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Memorial B1/B3 Mid 12m Faucet	DW/Grab	9-12-16	2:20a	Lead	P	1			0011A
Memorial East B Hall Left Fountain	DW/Grab	9-12-16	2:21a	Lead	P	1			002A
Memorial East B Hall Right Fountain	DW/Grab	9-12-16	2:21a	Lead	P	1			003A
South Albany Gym Left Fountain	DW/Grab	9-12-16	7:28a	Lead	P	1			014A
South Albany Gym Right Fountain	DW/Grab	9-12-16	7:28a	Lead	P	1			015A
South Shore Special Ed Faucet	DW/Grab	9-12-16	5:07a	Lead	P	1			016A
Calapooia Kitchen Faucet 1	DW/Grab	9-12-16	6:11a	Lead	P	1			017A
Calapooia Kitchen Faucet 2	DW/Grab	9-12-16	6:11a	Lead	P	1			018A
Calapooia Kitchen Faucet 3	DW/Grab	9-12-16	6:12a	Lead	P	1			019A
Calapooia Kitchen Faucet 4	DW/Grab	9-12-16	6:12a	Lead	P	1			020A

<b>Notes:</b>	<b>Preservation Check</b>				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

<b>Turn Around Time Requested (Rush incurs a Surcharge):</b> <input type="checkbox"/> NORMAL <input checked="" type="checkbox"/> RUSH	<b>Shipped Via:</b> ALG Courier	<b>Refrigerated</b> NA
--	------------------------------------	---------------------------

<b>Relinquished by:</b> Jessica Dilbone	<b>Date</b> 9-13-16	<b>Time</b> 1358	<b>Received by:</b> [Signature]	<b>Date</b> 9/13/16	<b>Time</b> 1358
<b>Relinquished by:</b> [Signature]	<b>Date</b> 9/13/16	<b>Time</b> 1601	<b>Received by:</b> [Signature]	<b>Date</b> 9/13/16	<b>Time</b> 1601
<b>Relinquished by:</b> [Signature]	<b>Date</b> 9/13/16	<b>Time</b> 1601	<b>Received by Laboratory:</b> [Signature]	<b>Date</b> 9/13/16	<b>Time</b> 1601

# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
 EUGENE, OREGON 97401  
 800-262-5973/541-485-8404 Fax 541-484-5995  
 Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



Delivering the  
just test results

NPUC

## CHAIN OF CUSTODY

<b>Attention:</b> Doug Pigman	<b>Client:</b> Greater Albany Public Schools
<b>Phone:</b> 541-967-4513	<b>Address:</b> 3610 Grand Prairie
<b>Email:</b> <a href="mailto:doug.pigman@albany.k12.or.us">doug.pigman@albany.k12.or.us</a>	<b>City, State, Zip:</b> Albany, OR 97322
<b>Client Project:</b> Rushed Samples	<b>Sampler:</b> Print Jessica Dilbone
	<b>Sampler:</b> Signature Jessica Dilbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Fir Grove Library South Faucet	DW/Grab	9-9-16	3:21p	Lead	P	1			021A
Sunrise Resource Rm Faucet	DW/Grab	9-12-16	5:26a	Lead	P	1			022A
Sunrise Rm 13 Faucet	DW/Grab	9-12-16	5:28a	Lead	P	1			023A
Sunrise Rm 10 Faucet	DW/Grab	9-12-16	5:30a	Lead	P	1			024A
Sunrise Rm 1 Fountain	DW/Grab	9-12-16	5:32a	Lead	P	1			025A
Sunrise Rm 2 Faucet	DW/Grab	9-12-16	5:33a	Lead	P	1			026A
Tangent Rm 3 SDF	DW/Grab	9-12-16	12:43a	Lead	P	1			027A
Tangent Rm 5 SDF	DW/Grab	9-12-16	12:45a	Lead	P	1			028A
Tangent Rm 11 Faucet	DW/Grab	9-12-16	12:48a	Lead	P	1			029A
	DW/Grab			Lead	P	1			

<b>Notes:</b>	<b>Preservation Check</b>				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

<b>Turn Around Time Requested (Rush incurs a Surcharge):</b>		<b>Shipped Via:</b>		<b>Refrigerated</b>	
<input type="checkbox"/> NORMAL _____ <input checked="" type="checkbox"/> RUSH _____		ALG Courier		NA	
<b>Relinquished by:</b>	<b>Date</b>	<b>Time</b>	<b>Received by:</b>	<b>Date</b>	<b>Time</b>
Jessica Dilbone	9-13-16	1358			
<b>Relinquished by:</b>	<b>Date</b>	<b>Time</b>	<b>Received by:</b>	<b>Date</b>	<b>Time</b>
			John J.	9/13/16	1358
<b>Relinquished by:</b>	<b>Date</b>	<b>Time</b>	<b>Received by Laboratory:</b>	<b>Date</b>	<b>Time</b>
John J.	9/13/16	1601		9/13/16	1601