



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

August 15, 2016

Doug Pigman
Greater Albany Public Schools
3610 Grand Prairie
Albany, OR 97322
TEL: (541) 967-4513
FAX

RE: Lafayette

Order No.: 1607493

Dear Doug Pigman:

Analytical Laboratory Group received 30 sample(s) on 7/12/2016 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reever Morghan'.

Kimberly Reever Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 1607493
Date: 8/15/2016

CLIENT: Greater Albany Public Schools
Project: Lafayette

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.



WO#: 1607493
CLIENT: Greater Albany Public Schools
Project: Lafayette
PWS Number:
Sample Source:

Received Date: 7/12/2016 3:00:00 PM
Sampler Name: Jessica Dilbone and Kristina
Matrix: Drinking Water
Sample Type:

Lab ID: 1607493-001 **Client Sample ID:** Rm 1 Sink **Collection Date:** 7/11/2016 2:57:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00995	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-002 **Client Sample ID:** Rm 2 Sink **Collection Date:** 7/11/2016 2:58:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0102	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-003 **Client Sample ID:** Rm 3 Sink **Collection Date:** 7/11/2016 3:01:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0223	0.0200	0.00400	*	mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-004 **Client Sample ID:** Rm 4 Sink **Collection Date:** 7/11/2016 3:02:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0116	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-005 **Client Sample ID:** Rm 5 Sink **Collection Date:** 7/11/2016 3:03:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00252	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-006 **Client Sample ID:** Rm 6 Sink **Collection Date:** 7/11/2016 3:03:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00450	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-007 **Client Sample ID:** Rm 7 Sink **Collection Date:** 7/11/2016 3:05:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0112	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-008 **Client Sample ID:** Rm 8 Sink **Collection Date:** 7/11/2016 3:06:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00869	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607493
CLIENT: Greater Albany Public Schools
Project: Lafayette
PWS Number:
Sample Source:

Received Date: 7/12/2016 3:00:00 PM
Sampler Name: Jessica Dilbone and Kristina
Matrix: Drinking Water
Sample Type:

Lab ID: 1607493-009 **Client Sample ID:** Rm 9 Sink **Collection Date:** 7/11/2016 3:06:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0249	0.0200	0.00400	*	mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-010 **Client Sample ID:** Rm 10 Sink **Collection Date:** 7/11/2016 3:07:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00215	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-011 **Client Sample ID:** Rm 11 Sink **Collection Date:** 7/11/2016 3:15:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-012 **Client Sample ID:** Rm 12 Sink **Collection Date:** 7/11/2016 3:15:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00791	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-013 **Client Sample ID:** Rm 13 Sink **Collection Date:** 7/11/2016 3:17:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-014 **Client Sample ID:** Rm 14 Sink **Collection Date:** 7/11/2016 3:17:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-015 **Client Sample ID:** Rm 15 Sink **Collection Date:** 7/11/2016 3:18:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607493
CLIENT: Greater Albany Public Schools
Project: Lafayette
PWS Number:
Sample Source:

Received Date: 7/12/2016 3:00:00 PM
Sampler Name: Jessica Dilbone and Kristina
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00260	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0205	0.0200	0.00400	*	mg/L	8/13/2016 7:07:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00207	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00385	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607493
CLIENT: Greater Albany Public Schools
Project: Lafayette
PWS Number:
Sample Source:

Received Date: 7/12/2016 3:00:00 PM
Sampler Name Jessica Dilbone and Kristina
Matrix: Drinking Water
Sample Type:

Lab ID: 1607493-024 **Client Sample ID** Lobby Entrance Fountain **Collection Date:** 7/11/2016 2:54:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-025 **Client Sample ID** Fountain Office Hall **Collection Date:** 7/11/2016 2:54:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00588	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-026 **Client Sample ID** Kitchen Sink A **Collection Date:** 7/11/2016 3:06:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-027 **Client Sample ID** Kitchen Sink B **Collection Date:** 7/11/2016 3:06:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-028 **Client Sample ID** Lounge Sink **Collection Date:** 7/11/2016 3:10:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00923	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-029 **Client Sample ID** Music Sink Center Wall **Collection Date:** 7/11/2016 3:04:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0148	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Lab ID: 1607493-030 **Client Sample ID** Staff Bathroom Sink **Collection Date:** 7/11/2016 2:56:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/13/2016 7:07:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1607493
 15-Aug-16

Client: Greater Albany Public Schools
Project: Lafayette

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607493-001A	Rm 1 Sink	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607493-002A	Rm 2 Sink			Lead	A
	1607493-003A	Rm 3 Sink			Lead	A
	1607493-004A	Rm 4 Sink			Lead	A
	1607493-005A	Rm 5 Sink			Lead	A
	1607493-006A	Rm 6 Sink			Lead	A
	1607493-007A	Rm 7 Sink			Lead	A
	1607493-008A	Rm 8 Sink			Lead	A
	1607493-009A	Rm 9 Sink			Lead	A
	1607493-010A	Rm 10 Sink			Lead	A
	1607493-011A	Rm 11 Sink			Lead	A
	1607493-012A	Rm 12 Sink			Lead	A
	1607493-013A	Rm 13 Sink			Lead	A
	1607493-014A	Rm 14 Sink			Lead	A
	1607493-015A	Rm 15 Sink			Lead	A
	1607493-016A	Rm 16 Sink			Lead	A
	1607493-017A	Rm 17 Sink			Lead	A
	1607493-018A	Rm 18 Sink			Lead	A
	1607493-019A	Central Hall Fountain			Lead	A
	1607493-020A	Cafe Fountain			Lead	A
	1607493-021A	North Hall Fountain			Lead	A
	1607493-022A	Staff Rm Sink			Lead	A
	1607493-023A	Staff/office rm sink			Lead	A
	1607493-024A	Lobby Entrance Fountain			Lead	A
	1607493-025A	Fountain Office Hall			Lead	A
	1607493-026A	Kitchen Sink A			Lead	A
	1607493-027A	Kitchen Sink B			Lead	A
	1607493-028A	Lounge Sink			Lead	A
	1607493-029A	Music Sink Center Wall			Lead	A
	1607493-030A	Staff Bathroom Sink			Lead	A

ACCRED ORELAP A Accredited



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1607493

Date: 8/15/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- A Accredited by ORELAP
- C Value is below Minimum Compound Limit.
- E Value above quantitation range
- H Holding times for preparation or analysis exceeded
- LOD Limit of Detection
- MCL Maximum Contaminant Level
- NAR See note in Case Narrative
- ND Not Detected at the Reporting Limit
- PL Permit Limit
- R RPD outside accepted recovery limits
- RL Reporting Detection Limit
- U Samples with CalcVal < MDL
- W Sample container temperature is out of limit as specified at testcode

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@alglabsinc.com</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Lafayette</u>	Sampler: Print <u>Jessica Dilbone</u> <u>Kristina Broome</u>
Sampler: Signature	

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 1 Sink	DW/Grab	7-11	2:57	Lead	P	1			001A
Rm 2 Sink	DW/Grab	7-11	2:58	Lead	P	1			002A
Rm 3 Sink	DW/Grab	7-11	3:01	Lead	P	1			003A
Rm 4 Sink	DW/Grab	7-11	3:02	Lead	P	1			004A
Rm 5 Sink	DW/Grab	7-11	3:03	Lead	P	1			005A
Rm 6 Sink	DW/Grab	7-11	3:03	Lead	P	1			006A
Rm 7 Sink	DW/Grab	7-11	3:05	Lead	P	1			007A
Rm 8 Sink	DW/Grab	7-11	3:06	Lead	P	1			008A
Rm 9 Sink	DW/Grab	7-11	3:06	Lead	P	1			009A
Rm 10 Sink	DW/Grab	7-11	3:07	Lead	P	1			010A

Notes:

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG Courier</u>	Refrigerated <u>NA</u>
---	------------------------------------	---------------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
				<u>MF</u>	<u>7/12/16</u>
Relinquished by: <u>MF</u>	Date	Time	Received by Laboratory:	Date	Time
	<u>7/12/16</u>	<u>1500</u>		<u>[Signature]</u>	<u>7/12/16</u>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@alglabsinc.com</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Lafayette</u>	Sampler: Print <u>Jessica Dilbone</u> <u>Kristina Birdome</u>
	Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 11 Sink	DW/Grab	7-11	3:15	Lead	P	1			011A
Rm 12 Sink	DW/Grab	7-11	3:15	Lead	P	1			012A
Rm 13 Sink	DW/Grab	7-11	3:17	Lead	P	1			013A
Rm 14 Sink	DW/Grab	7-11	3:17	Lead	P	1			014A
Rm 15 Sink	DW/Grab	7-11	3:18	Lead	P	1			015A
Rm 16 Sink	DW/Grab	7-11	3:19	Lead	P	1			016A
Rm 17 Sink	DW/Grab	7-11	3:19	Lead	P	1			017A
Rm 18 Sink	DW/Grab	7-11	3:20	Lead	P	1			018A
Central Hall Fountain	DW/Grab	7-11	3:08	Lead	P	1			019A
Cafe Fountain	DW/Grab	7-11	3:02	Lead	P	1			020A

Notes:

Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG Courier</u>	Refrigerated <u>NA</u>	
Relinquished by:	Date Time	Received by:	Date Time
Relinquished by:	Date Time	Received by:	Date Time
Relinquished by:	Date Time	Received by Laboratory:	Date Time
<u>M F</u>	<u>7/12/16</u> <u>1500</u>	<u>[Signature]</u>	<u>7/12/16</u> <u>1500</u>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@alglabsinc.com</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Lafayette</u>	Sampler: Print <u>Jessica Dilbone</u> <u>Kristina Groome</u>
	Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
North Hall Fountain	DW/Grab	7-11	3:08	Lead	P	1			021A
Staff Rm Sink	DW/Grab	7-11	3:02	Lead	P	1			022A
Staff/office Rm Sink	DW/Grab	7-11	2:55	Lead	P	1			023A
Lobby Entrance Fountain	DW/Grab	7-11	2:54	Lead	P	1			024A
Fountain office hall	DW/Grab	7-11	2:54	Lead	P	1			025A
Kitchen sink A	DW/Grab	7-11	3:06	Lead	P	1			026A
Kitchen sink B	DW/Grab	7-11	3:06	Lead	P	1			027A
Lounge sink	DW/Grab	7-11	3:10	Lead	P	1			028A
music sink center wall	DW/Grab	7-11	3:04	Lead	P	1			029A
staff bathrooms sink	DW/Grab	7-11	2:56	Lead	P	1			030A

Notes:

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge):
 NORMAL RUSH

Shipped Via: ALG Courier Refrigerated: NA

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
				<u>MF</u>	<u>7/12/16</u>
Relinquished by: <u>MF</u>	Date	Time	Received by Laboratory:	Date	Time
	<u>7/12/16</u>	<u>1500</u>		<u>[Signature]</u>	<u>7/12/16</u>