



Delivering more than  
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

August 16, 2016

Doug Pigman  
Greater Albany Public Schools  
3610 Grand Prairie  
Albany, OR 97322  
TEL: (541) 967-4513  
FAX

RE: Liberty

Order No.: 1607753

Dear Doug Pigman:

Analytical Laboratory Group received 34 sample(s) on 7/15/2016 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan  
Quality Manager  
361 West 5th Ave  
Eugene, OR 97401



ALG ORELAP ID #OR100012  
361 West 5th Ave  
Eugene, OR 97401  
TEL: (541) 485-8404 FAX: (541) 484-5995  
Website:

## Case Narrative

WO#: 1607753  
Date: 8/16/2016

---

**CLIENT:** Greater Albany Public Schools  
**Project:** Liberty

---

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

**WO#:** 1607753  
**CLIENT:** Greater Albany Public Schools  
**Project:** Liberty  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/15/2016 10:36:00 AM  
**Sampler Name** Stephanie Dilbone Kelsey O'  
**Matrix:** Drinking Water  
**Sample Type:**

**Lab ID:** 1607753-001      **Client Sample ID** Rm 1 Fountain      **Collection Date:** 7/15/2016 5:57:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00612	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-002      **Client Sample ID** Rm 1 Sink      **Collection Date:** 7/15/2016 5:57:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00435	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-003      **Client Sample ID** Rm 2 Fountain      **Collection Date:** 7/15/2016 5:56:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-004      **Client Sample ID** Rm 2 Sink      **Collection Date:** 7/15/2016 5:55:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0122	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-005      **Client Sample ID** Rm 3 Fountain      **Collection Date:** 7/15/2016 5:56:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00710	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-006      **Client Sample ID** Rm 3 Sink      **Collection Date:** 7/15/2016 5:55:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-007      **Client Sample ID** Rm 4 Fountain      **Collection Date:** 7/15/2016 5:54:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00256	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-008      **Client Sample ID** Rm 4 Sink      **Collection Date:** 7/15/2016 5:54:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00730	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

**WO#:** 1607753  
**CLIENT:** Greater Albany Public Schools  
**Project:** Liberty  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/15/2016 10:36:00 AM  
**Sampler Name** Stephanie Dilbone Kelsey O'  
**Matrix:** Drinking Water  
**Sample Type:**

**Lab ID:** 1607753-009      **Client Sample ID** Rm 5 Fountain      **Collection Date:** 7/15/2016 5:53:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0123	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-010      **Client Sample ID** Rm 5 Sink      **Collection Date:** 7/15/2016 5:53:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00602	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-011      **Client Sample ID** Rm 6 Fountain      **Collection Date:** 7/15/2016 5:49:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-012      **Client Sample ID** Rm 6 Sink      **Collection Date:** 7/15/2016 5:49:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00418	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-013      **Client Sample ID** Rm 7 Sink      **Collection Date:** 7/15/2016 5:50:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-014      **Client Sample ID** Rm 8 Sink      **Collection Date:** 7/15/2016 5:50:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-015      **Client Sample ID** Rm 10 Fountain      **Collection Date:** 7/15/2016 5:52:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00608	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

**WO#:** 1607753  
**CLIENT:** Greater Albany Public Schools  
**Project:** Liberty  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/15/2016 10:36:00 AM  
**Sampler Name** Stephanie Dilbone Kelsey O'  
**Matrix:** Drinking Water  
**Sample Type:**

**Lab ID:** 1607753-016      **Client Sample ID** Rm 10 Sink      **Collection Date:** 7/15/2016 5:52:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-017      **Client Sample ID** Rm 12 Fountain      **Collection Date:** 7/15/2016 6:02:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-018      **Client Sample ID** Rm 12 Sink      **Collection Date:** 7/15/2016 6:02:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00228	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-019      **Client Sample ID** Rm 14 Fountain      **Collection Date:** 7/15/2016 6:04:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00314	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-020      **Client Sample ID** Rm 14 Sink      **Collection Date:** 7/15/2016 6:04:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0152	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-021      **Client Sample ID** Rm 15 Fountain      **Collection Date:** 7/15/2016 6:05:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0169	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-022      **Client Sample ID** Rm 15 Sink      **Collection Date:** 7/15/2016 6:05:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00869	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-023      **Client Sample ID** Rm 16 Fountain      **Collection Date:** 7/15/2016 6:08:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Qualifiers:**

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

**WO#:** 1607753  
**CLIENT:** Greater Albany Public Schools  
**Project:** Liberty  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/15/2016 10:36:00 AM  
**Sampler Name** Stephanie Dilbone Kelsey O'  
**Matrix:** Drinking Water  
**Sample Type:**

**Lab ID:** 1607753-024      **Client Sample ID** Rm 16 Sink      **Collection Date:** 7/15/2016 6:08:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00911	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-025      **Client Sample ID** Rm 18 Sink      **Collection Date:** 7/15/2016 6:10:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00232	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-026      **Client Sample ID** Rm 19 Sink      **Collection Date:** 7/15/2016 6:10:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00201	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-027      **Client Sample ID** West Hall Fountain      **Collection Date:** 7/15/2016 5:48:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-028      **Client Sample ID** East Hall Fountain      **Collection Date:** 7/15/2016 6:03:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0106	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-029      **Client Sample ID** Gym Fountain      **Collection Date:** 7/15/2016 6:00:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-030      **Client Sample ID** Cafeteria Fountain      **Collection Date:** 7/15/2016 5:43:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00553	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Qualifiers:**

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

**WO#:** 1607753  
**CLIENT:** Greater Albany Public Schools  
**Project:** Liberty  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/15/2016 10:36:00 AM  
**Sampler Name:** Stephanie Dilbone Kelsey O'  
**Matrix:** Drinking Water  
**Sample Type:**

**Lab ID:** 1607753-031      **Client Sample ID:** Staff Room Sink      **Collection Date:** 7/15/2016 5:47:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/15/2016 3:45:00 PM	KG

**Lab ID:** 1607753-032      **Client Sample ID:** Diswashing Sink      **Collection Date:** 7/15/2016 5:44:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/15/2016 7:59:00 PM	PG

**Lab ID:** 1607753-033      **Client Sample ID:** Pot Sink      **Collection Date:** 7/15/2016 5:44:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/15/2016 7:59:00 PM	PG

**Lab ID:** 1607753-034      **Client Sample ID:** Handwashing Sink      **Collection Date:** 7/15/2016 5:45:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0131	0.0200	0.00200		mg/L	8/15/2016 7:59:00 PM	PG

**Qualifiers:**

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012  
 361 West 5th Ave  
 Eugene, OR 97401  
 TEL: (541) 485-8404 FAX: (541) 484-5995  
 Website:

## Accreditation Program Analytes Report

WO#: 1607753  
 16-Aug-16

**Client:** Greater Albany Public Schools  
**Project:** Liberty

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607753-001A	Rm 1 Fountain	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607753-002A	Rm 1 Sink			Lead	A
	1607753-003A	Rm 2 Fountain			Lead	A
	1607753-004A	Rm 2 Sink			Lead	A
	1607753-005A	Rm 3 Fountain			Lead	A
	1607753-006A	Rm 3 Sink			Lead	A
	1607753-007A	Rm 4 Fountain			Lead	A
	1607753-008A	Rm 4 Sink			Lead	A
	1607753-009A	Rm 5 Fountain			Lead	A
	1607753-010A	Rm 5 Sink			Lead	A
	1607753-011A	Rm 6 Fountain			Lead	A
	1607753-012A	Rm 6 Sink			Lead	A
	1607753-013A	Rm 7 Sink			Lead	A
	1607753-014A	Rm 8 Sink			Lead	A
	1607753-015A	Rm 10 Fountain			Lead	A
	1607753-016A	Rm 10 Sink			Lead	A
	1607753-017A	Rm 12 Fountain			Lead	A
	1607753-018A	Rm 12 Sink			Lead	A
	1607753-019A	Rm 14 Fountain			Lead	A
	1607753-020A	Rm 14 Sink			Lead	A
	1607753-021A	Rm 15 Fountain			Lead	A
	1607753-022A	Rm 15 Sink			Lead	A
	1607753-023A	Rm 16 Fountain			Lead	A
	1607753-024A	Rm 16 Sink			Lead	A
	1607753-025A	Rm 18 Sink			Lead	A
	1607753-026A	Rm 19 Sink			Lead	A
	1607753-027A	West Hall Fountain			Lead	A
	1607753-028A	East Hall Fountain			Lead	A
	1607753-029A	Gym Fountain			Lead	A
	1607753-030A	Cafeteria Fountain			Lead	A
	1607753-031A	Staff Room Sink			Lead	A

ORELAP A Accredited

ACCRED

Original #1607753# v1





ALG ORELAP ID #OR100012  
 361 West 5th Ave  
 Eugene, OR 97401  
 TEL: (541) 485-8404 FAX: (541) 484-5995  
 Website:

**Accreditation Program  
 Analytes Report**

WO#: 1607753  
 16-Aug-16

**Client:** Greater Albany Public Schools  
**Project:** Liberty

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607753-032A	Diswashing Sink	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607753-033A	Pot Sink			Lead	A
	1607753-034A	Handwashing Sink			Lead	A

ORELAP A Accredited

ACCRED



Delivering more than  
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

## Definition Base

WO#: 1607753

Date: 8/16/2016

---

### Definitions:

**% REC:** Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

**% RPD:** Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

**DF:** Dilution factor; the dilution factor applied to the prepared sample.

**DUP:** Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

**LCS:** Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

**LCSD:** The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

**MBLK:** Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

**MS:** Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

**MSD:** The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

**ND:** Not Detected. The analyte level is below the lowest point the laboratory can test for.

**PL:** Permit limit; only applicable to wastewater reports.

**PQL:** Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

**Qual:** Qualifier that applies to the analyte reported

---

Original

Page 10 of 11

**Definitions:**

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

**Qualifiers:**

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
 EUGENE, OREGON 97401  
 800-262-5973/541-485-8404 Fax 541-484-5995  
 Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



Delivering more than just test results

## CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@alglabsinc.com</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Liberty</u>	Sampler: <u>Print Stephanie Dilbone Kelsey O'Connell</u>
Sampler: Signature	

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 1 fountain	DW/Grab	7-15-16	5:57	Lead	P	1			001A
Rm 1 sink	DW/Grab	7-15	5:57	Lead	P	1			002A
Rm 2 fountain	DW/Grab	7-15	5:56	Lead	P	1			003A
Rm 2 sink	DW/Grab	7-15	5:56	Lead	P	1			004A
Rm 3 fountain	DW/Grab	7-15	5:55	Lead	P	1			005A
Rm 3 sink	DW/Grab	7-15	5:55	Lead	P	1			006A
Rm 4 fountain	DW/Grab	7-15	5:54	Lead	P	1			007A
Rm 4 sink	DW/Grab	7-15	5:54	Lead	P	1			008A
Rm 5 fountain	DW/Grab	7-15	5:53	Lead	P	1			009A
Rm 5 sink	DW/Grab	7-15	5:53	Lead	P	1			010A

Notes:

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>AIR CARRIER</u>	Refrigerated <u>NA</u>
---	------------------------------------	---------------------------

Relinquished by: <u>[Signature]</u>	Date	Time	Received by: <u>[Signature]</u>	Date	Time
	<u>7/15</u>	<u>7:30</u>		<u>7/15/16</u>	<u>0945</u>
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by: <u>[Signature]</u>	Date	Time	Received by Laboratory: <u>[Signature]</u>	Date	Time
	<u>7/15/16</u>	<u>1036</u>		<u>7/15/16</u>	<u>10:36</u>

# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



*Delivering more than just test results*

## CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@albanymk2.or.us</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Liberty</u>	Sampler: <u>Print Stephanie Dilbone Kehey O'Connell</u>
Sampler: Signature _____	

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 6 fountain	DW/Grab	7-15	5:49	Lead	P	1			011A
Rm 6 sink	DW/Grab	7-15	5:49	Lead	P	1			012A
Rm 7 sink	DW/Grab	7-15	5:50	Lead	P	1			013A
Rm 8 sink	DW/Grab	7-15	5:50	Lead	P	1			014A
Rm 10 fountain	DW/Grab	7-15	5:52	Lead	P	1			015A
Rm 10 sink	DW/Grab	7-15	5:52	Lead	P	1			016A
Rm 12 fountain	DW/Grab	7-15	6:02	Lead	P	1			017A
Rm 12 sink	DW/Grab	7-15	6:02	Lead	P	1			018A
Rm 14 fountain	DW/Grab	7-15	6:04	Lead	P	1			019A
Rm 14 sink	DW/Grab	7-15	6:04	Lead	P	1			020A

Notes:	<b>Preservation Check</b>				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG COURIER</u>	Refrigerated <u>NA</u>
---	------------------------------------	---------------------------

Relinquished by: <u>[Signature]</u>	Date	Time	Received by: <u>[Signature]</u>	Date	Time
	<u>7/15</u>	<u>7:30</u>		<u>7/15/16</u>	<u>0945</u>
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by: <u>[Signature]</u>	Date	Time	Received by Laboratory: <u>[Signature]</u>	Date	Time
	<u>7/15/16</u>	<u>1036</u>		<u>7/15/16</u>	<u>10:36</u>

# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
 EUGENE, OREGON 97401  
 800-262-5973/541-485-8404 Fax 541-484-5995  
 Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



*Delivering more than just test results.*

## CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@albanymk2.or.us</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Liberty</u>	Sampler: <u>Print Stephanie Dilbone Kelsey O'Connell</u>
Sampler: Signature	

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 15 fountain	DW/Grab	7-15	6:05	Lead	P	1			021A
Rm 15 sink	DW/Grab	7-15	6:05	Lead	P	1			022A
Rm 16 fountain	DW/Grab	7-15	6:08	Lead	P	1			023A
Rm 16 sink	DW/Grab	7-15	6:08	Lead	P	1			024A
Rm 18 sink	DW/Grab	7-15	6:10	Lead	P	1			025A
Rm 19 sink	DW/Grab	7-15	6:10	Lead	P	1			026A
west hall fountain	DW/Grab	7-15	5:48	Lead	P	1			027A
east hall fountain	DW/Grab	7-15	6:03	Lead	P	1			028A
Gym fountain	DW/Grab	7-15	6:00	Lead	P	1			029A
cafeteria fountain	DW/Grab	7-15	5:43	Lead	P	1			030A

Notes:	<b>Preservation Check</b>				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG Courier</u>	Refrigerated <u>NA</u>
Relinquished by: <u>[Signature]</u>	Date: <u>7/15</u> Time: <u>7:30</u>	Received by: <u>[Signature]</u> Date: <u>7/15/16</u> Time: <u>0945</u>
Relinquished by:	Date:    Time:	Received by:
Relinquished by: <u>[Signature]</u>	Date: <u>7/15/16</u> Time: <u>1036</u>	Received by Laboratory: <u>[Signature]</u> Date: <u>7/15/16</u> Time: <u>10:36</u>



# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
 EUGENE, OREGON 97401  
 800-262-5973/541-485-8404 Fax 541-484-5995  
 Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



Delivering more than just test results

## CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@albanymk2.org</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Liberty</u>	Sampler: Print <u>Stephanie Dilbone</u> <u>Kelsey O'Connell</u>
Sampler: Signature _____	

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
<u>Staff Room sink</u>	<u>DW/Grab</u>	<u>7-15</u>	<u>5:47</u>	<u>Lead</u>	<u>P</u>	<u>1</u>			<u>031A</u>
<u>Dishwashing sink</u>	<u>DW/Grab</u>	<u>7-15</u>	<u>5:44</u>	<u>Lead</u>	<u>P</u>	<u>1</u>			<u>032A</u>
<u>Pot sink</u>	<u>DW/Grab</u>	<u>7-15</u>	<u>5:44</u>	<u>Lead</u>	<u>P</u>	<u>1</u>			<u>033A</u>
<u>handwashing sink</u>	<u>DW/Grab</u>	<u>7-15</u>	<u>5:45</u>	<u>Lead</u>	<u>P</u>	<u>1</u>			<u>034A</u>
	<u>DW/Grab</u>			<u>Lead</u>	<u>P</u>	<u>1</u>			
	<u>DW/Grab</u>			<u>Lead</u>	<u>P</u>	<u>1</u>			
	<u>DW/Grab</u>			<u>Lead</u>	<u>P</u>	<u>1</u>			
	<u>DW/Grab</u>			<u>Lead</u>	<u>P</u>	<u>1</u>			
	<u>DW/Grab</u>			<u>Lead</u>	<u>P</u>	<u>1</u>			
	<u>DW/Grab</u>			<u>Lead</u>	<u>P</u>	<u>1</u>			

Notes:	<b>Preservation Check</b>				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG carrier</u>	Refrigerated: <u>NA</u>
---	---------------------------------	-------------------------

Relinquished by: <u>[Signature]</u>	Date	Time	Received by: <u>[Signature]</u>	Date	Time
	<u>7/15</u>	<u>7:30</u>		<u>7/15/16</u>	<u>0945</u>
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by: <u>[Signature]</u>	Date	Time	Received by Laboratory: <u>[Signature]</u>	Date	Time
	<u>7/15/16</u>	<u>10:36</u>		<u>7/15/16</u>	<u>10:36</u>