



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

August 23, 2016

Doug Pigman
Greater Albany Public Schools
3610 Grand Prairie
Albany, OR 97322
TEL: (541) 967-4513
FAX

RE: NAMS

Order No.: 1607B28

Dear Doug Pigman:

Analytical Laboratory Group received 47 sample(s) on 7/22/2016 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: **1607B28**

Date: **8/23/2016**

CLIENT: Greater Albany Public Schools

Project: NAMS

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

Report Revised on 8/23/2016 to correct an error in the analysis date for samples 1607B28-041 to 1607B28-047.



WO#: 1607B28
CLIENT: Greater Albany Public Schools
Project: NAMS
PWS Number:
Sample Source:

Received Date: 7/22/2016 2:06:00 PM
Sampler Name Jessica Dilbone Stephanie Dil
Matrix: Drinking Water
Sample Type:

Lab ID: 1607B28-001 **Client Sample ID** Rm 1 Sink **Collection Date:** 7/22/2016 6:39:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00453	0.0200	0.00200		mg/L	8/17/2016 8:30:00 PM	PG

Lab ID: 1607B28-002 **Client Sample ID** Work Rm Sink **Collection Date:** 7/22/2016 6:40:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0172	0.0200	0.00200		mg/L	8/17/2016 8:30:00 PM	PG

Lab ID: 1607B28-003 **Client Sample ID** Rm 3 Sink **Collection Date:** 7/22/2016 6:44:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00406	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-004 **Client Sample ID** Rm 13 Sink **Collection Date:** 7/22/2016 6:45:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00253	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-005 **Client Sample ID** Rm 11 Sink **Collection Date:** 7/22/2016 6:47:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00323	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-006 **Client Sample ID** Rm 10 Sink **Collection Date:** 7/22/2016 6:49:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00604	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-007 **Client Sample ID** Rm 19 Sink **Collection Date:** 7/22/2016 6:55:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0244	0.0200	0.00400	*	mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-008 **Client Sample ID** Rm 10 Hall Fntn **Collection Date:** 7/22/2016 6:49:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607B28
CLIENT: Greater Albany Public Schools
Project: NAMS
PWS Number:
Sample Source:

Received Date: 7/22/2016 2:06:00 PM
Sampler Name Jessica Dilbone Stephanie Dil
Matrix: Drinking Water
Sample Type:

Lab ID: 1607B28-009 **Client Sample ID** Rm 19 Hall Fntn **Collection Date:** 7/22/2016 6:55:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0142	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-010 **Client Sample ID** Rm 18 Sink **Collection Date:** 7/22/2016 6:59:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0197	0.0200	0.00400		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-011 **Client Sample ID** Rm 17 Sink **Collection Date:** 7/22/2016 7:00:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0120	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-012 **Client Sample ID** Rm 16 Sink **Collection Date:** 7/22/2016 7:03:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0101	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-013 **Client Sample ID** Library Wrk Rm Sink **Collection Date:** 7/22/2016 6:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00781	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-014 **Client Sample ID** Library Hall Fntn **Collection Date:** 7/22/2016 6:28:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0141	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-015 **Client Sample ID** Office Sink **Collection Date:** 7/22/2016 6:23:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00207	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

WO#: 1607B28
CLIENT: Greater Albany Public Schools
Project: NAMS
PWS Number:
Sample Source:

Received Date: 7/22/2016 2:06:00 PM
Sampler Name Jessica Dilbone Stephanie Dil
Matrix: Drinking Water
Sample Type:

Lab ID: 1607B28-016 **Client Sample ID** First Aid Sink **Collection Date:** 7/22/2016 6:23:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00422	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-017 **Client Sample ID** Store Sink **Collection Date:** 7/22/2016 6:25:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.175	0.0200	0.0200	*	mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-018 **Client Sample ID** Bookroom Sink **Collection Date:** 7/22/2016 7:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.121	0.0200	0.0200	*	mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-019 **Client Sample ID** Rm 2 Hall Fntn **Collection Date:** 7/22/2016 6:35:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-020 **Client Sample ID** Staff Rm Sink **Collection Date:** 7/22/2016 7:19:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00963	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-021 **Client Sample ID** Kitchen Hand Sink **Collection Date:** 7/22/2016 7:13:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00939	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-022 **Client Sample ID** Kitchen Dish Sink **Collection Date:** 7/22/2016 7:13:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00388	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-023 **Client Sample ID** Kitchen Pot Sink **Collection Date:** 7/22/2016 7:15:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



WO#: 1607B28
CLIENT: Greater Albany Public Schools
Project: NAMS
PWS Number:
Sample Source:

Received Date: 7/22/2016 2:06:00 PM
Sampler Name: Jessica Dilbone Stephanie Dil
Matrix: Drinking Water
Sample Type:

Lab ID: 1607B28-024 **Client Sample ID:** Kitchen Handwash Sink 2 **Collection Date:** 7/22/2016 7:15:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00566	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-025 **Client Sample ID:** Band Rm Sink **Collection Date:** 7/22/2016 7:17:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00712	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-026 **Client Sample ID:** Cafeteria Fntn **Collection Date:** 7/22/2016 7:11:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-027 **Client Sample ID:** Lobby Fntn **Collection Date:** 7/22/2016 6:24:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-028 **Client Sample ID:** Rm 26 Sink **Collection Date:** 7/22/2016 7:19:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-029 **Client Sample ID:** Rm 27 Sink **Collection Date:** 7/22/2016 7:19:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00575	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-030 **Client Sample ID:** Rm 29 Sink **Collection Date:** 7/22/2016 7:26:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00211	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

Revision v1
Page 6 of 13

WO#: 1607B28
CLIENT: Greater Albany Public Schools
Project: NAMS
PWS Number:
Sample Source:

Received Date: 7/22/2016 2:06:00 PM
Sampler Name Jessica Dilbone Stephanie Dil
Matrix: Drinking Water
Sample Type:

Lab ID: 1607B28-031 **Client Sample ID** Gym Hall Fntn **Collection Date:** 7/22/2016 7:15:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-032 **Client Sample ID** Girls Locker Rm Fount **Collection Date:** 7/22/2016 7:10:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00834	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-033 **Client Sample ID** Boys Locker rm Fntn **Collection Date:** 7/22/2016 7:12:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-034 **Client Sample ID** Upper Gym Fntn **Collection Date:** 7/22/2016 7:13:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00742	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-035 **Client Sample ID** Rm 24 Sink **Collection Date:** 7/22/2016 7:04:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0182	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-036 **Client Sample ID** Home Ec Sink 1 **Collection Date:** 7/22/2016 6:59:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0270	0.0200	0.00400	*	mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-037 **Client Sample ID** Home Ec Sink 2 **Collection Date:** 7/22/2016 6:59:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00325	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-038 **Client Sample ID** Home Ec Sink 3 **Collection Date:** 7/22/2016 6:59:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00434	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607B28
CLIENT: Greater Albany Public Schools
Project: NAMS
PWS Number:
Sample Source:

Received Date: 7/22/2016 2:06:00 PM
Sampler Name Jessica Dilbone Stephanie Dil
Matrix: Drinking Water
Sample Type:

Lab ID: 1607B28-039 **Client Sample ID** Home Ec Sink 4 **Collection Date:** 7/22/2016 7:01:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00624	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-040 **Client Sample ID** Home Ec Sink 5 **Collection Date:** 7/22/2016 7:01:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0132	0.0200	0.00200		mg/L	8/20/2016 6:54:00 AM	KG

Lab ID: 1607B28-041 **Client Sample ID** Home Ec Sink 6 **Collection Date:** 7/22/2016 7:03:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0265	0.0200	0.00400	*	mg/L	8/20/2016 12:30:00 PM	PG

Lab ID: 1607B28-042 **Client Sample ID** Home Ec Sink 7 **Collection Date:** 7/22/2016 7:03:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0263	0.0200	0.00400	*	mg/L	8/20/2016 12:30:00 PM	PG

Lab ID: 1607B28-043 **Client Sample ID** Rm 31 Sink **Collection Date:** 7/22/2016 6:51:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00349	0.0200	0.00200		mg/L	8/20/2016 12:30:00 PM	PG

Lab ID: 1607B28-044 **Client Sample ID** Rm 32 Sink **Collection Date:** 7/22/2016 6:52:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00932	0.0200	0.00200		mg/L	8/20/2016 12:30:00 PM	PG

Lab ID: 1607B28-045 **Client Sample ID** Rm 20 Sink **Collection Date:** 7/22/2016 6:56:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00200	0.0200	0.00200		mg/L	8/20/2016 12:30:00 PM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported **8/23/2016**

WO#: 1607B28
CLIENT: Greater Albany Public Schools
Project: NAMS
PWS Number:
Sample Source:

Received Date: 7/22/2016 2:06:00 PM
Sampler Name: Jessica Dilbone Stephanie Dil
Matrix: Drinking Water
Sample Type:

Lab ID: 1607B28-046 **Client Sample ID:** Rm 21 Sink **Collection Date:** 7/22/2016 6:58:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0796	0.0200	0.00800	*	mg/L	8/20/2016 12:30:00 PM	PG

Lab ID: 1607B28-047 **Client Sample ID:** Rm 22 Sink **Collection Date:** 7/22/2016 7:02:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00833	0.0200	0.00200		mg/L	8/20/2016 12:30:00 PM	PG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1607B28
 23-Aug-16

Client: Greater Albany Public Schools
Project: NAMS

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607B28-001A	Rm 1 Sink	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607B28-002A	Work Rm Sink			Lead	A
	1607B28-003A	Rm 3 Sink			Lead	A
	1607B28-004A	Rm 13 Sink			Lead	A
	1607B28-005A	Rm 11 Sink			Lead	A
	1607B28-006A	Rm 10 Sink			Lead	A
	1607B28-007A	Rm 19 Sink			Lead	A
	1607B28-008A	Rm 10 Hall Fntn			Lead	A
	1607B28-009A	Rm 19 Hall Fntn			Lead	A
	1607B28-010A	Rm 18 Sink			Lead	A
	1607B28-011A	Rm 17 Sink			Lead	A
	1607B28-012A	Rm 16 Sink			Lead	A
	1607B28-013A	Library Wrk Rm Sink			Lead	A
	1607B28-014A	Library Hall Fntn			Lead	A
	1607B28-015A	Office Sink			Lead	A
	1607B28-016A	First Aid Sink			Lead	A
	1607B28-017A	Store Sink			Lead	A
	1607B28-018A	Bookroom Sink			Lead	A
	1607B28-019A	Rm 2 Hall Fntn			Lead	A
	1607B28-020A	Staff Rm Sink			Lead	A
	1607B28-021A	Kitchen Hand Sink			Lead	A
	1607B28-022A	Kitchen Dish Sink			Lead	A
	1607B28-023A	Kitchen Pot Sink			Lead	A
	1607B28-024A	Kitchen Handwash Sink 2			Lead	A
	1607B28-025A	Band Rm Sink			Lead	A
	1607B28-026A	Cafeteria Fntn			Lead	A
	1607B28-027A	Lobby Fntn			Lead	A
	1607B28-028A	Rm 26 Sink			Lead	A
	1607B28-029A	Rm 27 Sink			Lead	A
	1607B28-030A	Rm 29 Sink			Lead	A

ORELAP A Accredited

ACCRED



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1607B28
 23-Aug-16

Client: Greater Albany Public Schools
Project: NAMS

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607B28-031A	Gym Hall Fntn	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607B28-032A	Girls Locker Rm Fount			Lead	A
	1607B28-033A	Boys Locker rm Fntn			Lead	A
	1607B28-034A	Upper Gym Fntn			Lead	A
	1607B28-035A	Rm 24 Sink			Lead	A
	1607B28-036A	Home Ec Sink 1			Lead	A
	1607B28-037A	Home Ec Sink 2			Lead	A
	1607B28-038A	Home Ec Sink 3			Lead	A
	1607B28-039A	Home Ec Sink 4			Lead	A
	1607B28-040A	Home Ec Sink 5			Lead	A
	1607B28-041A	Home Ec Sink 6			Lead	A
	1607B28-042A	Home Ec Sink 7			Lead	A
	1607B28-043A	Rm 31 Sink			Lead	A
	1607B28-044A	Rm 32 Sink			Lead	A
	1607B28-045A	Rm 20 Sink			Lead	A
	1607B28-046A	Rm 21 Sink			Lead	A
	1607B28-047A	Rm 22 Sink			Lead	A



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1607B28

Date: 8/23/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported

Definition Base

WO#: 1607B28
Date: 8/23/2016

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@alglabsinc.com</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>NAMS</u>	Sampler: Print <u>Jessica Dilbone, Stephanie Kelsey O'Connell, Dilbone</u> Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 1 sink	DW/Grab	7-22	6:39a	Lead	P	1			001A
Work Rm Sink	DW/Grab	7-22	6:40a	Lead	P	1			002A
Rm 3 sink	DW/Grab	7-22	6:44a	Lead	P	1			003A
Rm 13 sink	DW/Grab	7-22	6:45a	Lead	P	1			004A
Rm 12 sink	DW/Grab	7-22		Lead	P	1			
Rm 11 sink	DW/Grab	7-22	6:47a	Lead	P	1			005A
Rm 10 sink	DW/Grab	7-22	6:49a	Lead	P	1			006A
Rm 1a sink	DW/Grab	7-22	6:55a	Lead	P	1			007A
Rm 10 hall fount	DW/Grab	7-22	6:49a	Lead	P	1			008A
Rm 1a hall fount	DW/Grab	7-22	6:55a	Lead	P	1			009A

Notes:

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG COURIER</u>	Refrigerated: <u>NA</u>
---	---------------------------------	-------------------------

Relinquished by: <u>Jessica Dilbone</u>	Date	Time	Received by: <u>Jason B. Lima</u>	Date	Time
				<u>7/22/16</u>	<u>1320</u>
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by: <u>Jason B. Lima</u>	Date	Time	Received by Laboratory:	Date	Time
	<u>7/22/16</u>	<u>1406</u>	<u>[Signature]</u>	<u>7/22/16</u>	<u>1406</u>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@albanymk202.us</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project:	Sampler: Print <u>Jessica Dilbone, Stephanie Dilbone, Kelsey O'Connell</u>
	Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 18 sink	DW/Grab	7-22	6:59a	Lead	P	1			010A
Rm 17 sink	DW/Grab	7-22	7:00a	Lead	P	1			011A
Rm 16 sink	DW/Grab	7-22	7:03a	Lead	P	1			012A
library wrk Rm sink	DW/Grab	7-22	6:30a	Lead	P	1			013A
library hall fount.	DW/Grab	7-22	6:28a	Lead	P	1			014A
office sink	DW/Grab	7-22	6:23a	Lead	P	1			015A
first aid sink	DW/Grab	7-22	6:23a	Lead	P	1			016A
store counselors sink	DW/Grab	7-22	6:25a	Lead	P	1			017A
Bookroom sink	DW/Grab	7-22	7:30a	Lead	P	1			018A
Rm 2 hall fount.	DW/Grab	7-22	6:35a	Lead	P	1			019A

Notes:

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		Refrigerated	
<input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH		<u>ALG COURIER</u>		<u>NA</u>	
Relinquished by:	Date	Time	Received by:	Date	Time
<u>Jessica Dilbone</u>			<u>[Signature]</u>	<u>7/22/16</u>	<u>1320</u>
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>[Signature]</u>	<u>7/22/16</u>	<u>1406</u>	<u>[Signature]</u>	<u>7/22/16</u>	<u>1406</u>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@albanymk2.or.us</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>NAMS</u>	Sampler: Print <u>Jessica Dilbone</u> Sampler: Signature _____

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Staff Rm Sink	DW/Grab	7-22-16	7:19a	Lead	P	1			020A
Kitchen hand sink	DW/Grab	7-22	7:13a	Lead	P	1			021A
Kitchen dish sink	DW/Grab	7-22	7:13a	Lead	P	1			022A
Kitchen Pot sink	DW/Grab	7-22	7:15a	Lead	P	1			023A
Kitchen Hand Wash Sink	DW/Grab	7-22	7:15a	Lead	P	1			024A
Band Rm Sink	DW/Grab	7-22	7:17a	Lead	P	1			025A
cafeteria fountain	DW/Grab	7-22	7:11a	Lead	P	1			026A
lobby fountain	DW/Grab	7-22	6:24a	Lead	P	1			027A
Rm 26 sink	DW/Grab	7-22	7:19a	Lead	P	1			028A
Rm 27 sink	DW/Grab	7-22	7:19a	Lead	P	1			029A

Notes:	Preservation Check																																																		
	<table border="1" style="width:100%"> <thead> <tr> <th>Lab ID</th> <th>Date/Time</th> <th>Pre-Preserved</th> <th>pH</th> <th>Tech</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	Lab ID	Date/Time	Pre-Preserved	pH	Tech																																													
Lab ID	Date/Time	Pre-Preserved	pH	Tech																																															

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG COURIER</u>	Refrigerated: <u>NA</u>
---	---------------------------------	-------------------------

Relinquished by: <u>Jessica Dilbone</u>	Date	Time	Received by: <u>Jess B...</u>	Date	Time
				<u>7/22/16</u>	<u>1320</u>
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by: <u>Jess B...</u>	Date	Time	Received by Laboratory:	Date	Time
	<u>7/22/16</u>	<u>1406</u>	<u>[Signature]</u>	<u>7/22/16</u>	<u>1406</u>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@albanymk2002us</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>NAMS</u>	Sampler: <u>Print Stephanie, Jessica Dilbone, Kelsey</u> Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 29 snk	DW/Grab	7-22	7:26a	Lead	P	1			030A
Rm 29	DW/Grab			Lead	P	1			
Gym hall fountain	DW/Grab		7:15a	Lead	P	1			031A
Girls locker Rm fount	DW/Grab		7:10a	Lead	P	1			032A
Boys locker Rm fount	DW/Grab		7:12a	Lead	P	1			033A
upper gym fountain	DW/Grab		7:13a	Lead	P	1			034A
Rm 24 sink	DW/Grab		7:04a	Lead	P	1			035A
Home ec sink #1	DW/Grab		6:59a	Lead	P	1			036A
Home ec sink 2	DW/Grab		6:59a	Lead	P	1			037A
home ec sink 3	DW/Grab	✓	6:59a	Lead	P	1			038A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG COURIER</u>	Refrigerated: <u>NA</u>
Relinquished by: <u>Jessica Dilbone</u>	Received by: <u>Jess B Dilbone</u>	Date: <u>7/22/16</u> Time: <u>1320</u>
Relinquished by: <u>Jess B Dilbone</u>	Received by: <u>Jess B Dilbone</u>	Date: Time:
Relinquished by: <u>Jess B Dilbone</u>	Received by Laboratory: <u>Jess B Dilbone</u>	Date: <u>7/22/16</u> Time: <u>1406</u>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@alglabsinc.com</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>NAMS</u>	Sampler: Print <u>Keisey Jessica Dillbone O'Connell Stephanie Dillbone</u> Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Home ec sink 4	DW/Grab	7-22-16	7:01a	Lead	P	1			039A
Home ec sink 5	DW/Grab		7:01a	Lead	P	1			040A
Home ec sink 6	DW/Grab		7:03a	Lead	P	1			041A
Home ec sink 7	DW/Grab		7:03a	Lead	P	1			042A
Rm 31 sink	DW/Grab		6:51a	Lead	P	1			043A
Rm 32 sink	DW/Grab		6:52a	Lead	P	1			044A
Rm Sink	DW/Grab			Lead	P	1			
Rm 20 sink	DW/Grab		6:50a	Lead	P	1			045A
Rm 21 sink	DW/Grab		6:50a	Lead	P	1			046A
Rm 22 sink	DW/Grab	✓	7:02a	Lead	P	1			047A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG COURIER</u>	Refrigerated <u>NA</u>
Relinquished by: <u>Jessica Dillbone</u>	Received by: <u>[Signature]</u>	Date: <u>7/22/16</u> Time: <u>1320</u>
Relinquished by:	Received by:	Date: Time:
Relinquished by: <u>[Signature]</u>	Received by Laboratory: <u>[Signature]</u>	Date: <u>7/22/16</u> Time: <u>1406</u>