



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

September 27, 2016

Doug Pigman
Greater Albany Public Schools
3610 Grand Prairie
Albany, OR 97322
TEL: (541) 967-4513
FAX

RE: North Albany Middle

Order No.: 1609583

Dear Doug Pigman:

Analytical Laboratory Group received 33 sample(s) on 9/13/2016 for the analyses presented in the following report.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: **1609583**

Date: **9/27/2016**

CLIENT: Greater Albany Public Schools

Project: North Albany Middle

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

WO#: 1609583
CLIENT: Greater Albany Public Schools
Project: North Albany Middle
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609583-001 **Client Sample ID:** Art West Faucet **Collection Date:** 9/12/2016 4:19:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00306	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG
------	-----------	---------	--------	---------	--	------	----------------------	----

Lab ID: 1609583-002 **Client Sample ID:** Art Middle Faucet **Collection Date:** 9/12/2016 4:19:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00447	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG
------	-----------	---------	--------	---------	--	------	----------------------	----

Lab ID: 1609583-003 **Client Sample ID:** Art East Faucet **Collection Date:** 9/12/2016 4:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00326	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG
------	-----------	---------	--------	---------	--	------	----------------------	----

Lab ID: 1609583-004 **Client Sample ID:** Rm 27 Faucet **Collection Date:** 9/12/2016 4:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00265	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG
------	-----------	---------	--------	---------	--	------	----------------------	----

Lab ID: 1609583-005 **Client Sample ID:** Rm 26 Faucet **Collection Date:** 9/12/2016 4:19:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00351	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG
------	-----------	---------	--------	---------	--	------	----------------------	----

Lab ID: 1609583-006 **Client Sample ID:** Rm 32 Faucet 1 **Collection Date:** 9/12/2016 4:25:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00469	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG
------	-----------	---------	--------	---------	--	------	----------------------	----

Lab ID: 1609583-007 **Client Sample ID:** Rm 32 Faucet 3 **Collection Date:** 9/12/2016 4:25:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00300	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG
------	-----------	---------	--------	---------	--	------	----------------------	----

Lab ID: 1609583-008 **Client Sample ID:** Rm 32 Faucet 4 **Collection Date:** 9/12/2016 4:26:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG
------	-----------	----	--------	---------	--	------	----------------------	----

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 1609583
CLIENT: Greater Albany Public Schools
Project: North Albany Middle
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609583-009 **Client Sample ID:** Rm 32 Faucet 5 **Collection Date:** 9/12/2016 4:27:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00271	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG

Lab ID: 1609583-010 **Client Sample ID:** Rm 32 Faucet 6 **Collection Date:** 9/12/2016 4:27:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00210	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG

Lab ID: 1609583-011 **Client Sample ID:** Rm 31 Faucet 1 **Collection Date:** 9/12/2016 4:28:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG

Lab ID: 1609583-012 **Client Sample ID:** Rm 31 Faucet 3 **Collection Date:** 9/12/2016 4:29:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00455	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG

Lab ID: 1609583-013 **Client Sample ID:** Rm 31 Faucet 4 **Collection Date:** 9/12/2016 4:29:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00234	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG

Lab ID: 1609583-014 **Client Sample ID:** Rm 30 Faucet **Collection Date:** 9/12/2016 4:31:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG

Lab ID: 1609583-015 **Client Sample ID:** Rm 11 Faucet **Collection Date:** 9/12/2016 4:34:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00623	0.0200	0.00200		mg/L	9/24/2016 8:01:00 AM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 1609583
CLIENT: Greater Albany Public Schools
Project: North Albany Middle
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609583-016 **Client Sample ID:** Rm 13 Faucet **Collection Date:** 9/12/2016 4:35:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0144	0.0200	0.00200		mg/L	9/24/2016 9:25:00 PM	KG

Lab ID: 1609583-017 **Client Sample ID:** Rm 1 Faucet **Collection Date:** 9/12/2016 4:38:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0243	0.0200	0.00400	*	mg/L	9/24/2016 9:25:00 PM	KG

Lab ID: 1609583-018 **Client Sample ID:** Rm 22 Faucet 2 **Collection Date:** 9/12/2016 4:40:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00369	0.0200	0.00200		mg/L	9/24/2016 9:25:00 PM	KG

Lab ID: 1609583-019 **Client Sample ID:** Rm 22 Faucet 3 **Collection Date:** 9/12/2016 4:40:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00454	0.0200	0.00200		mg/L	9/24/2016 9:25:00 PM	KG

Lab ID: 1609583-020 **Client Sample ID:** Rm 22 Faucet 4 **Collection Date:** 9/12/2016 4:41:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00942	0.0200	0.00200		mg/L	9/24/2016 9:25:00 PM	KG

Lab ID: 1609583-021 **Client Sample ID:** Rm 22 Faucet 5 **Collection Date:** 9/12/2016 4:41:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00588	0.0200	0.00200		mg/L	9/24/2016 9:25:00 PM	KG

Lab ID: 1609583-022 **Client Sample ID:** Rm 22 Faucet 6 **Collection Date:** 9/12/2016 4:42:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00348	0.0200	0.00200		mg/L	9/24/2016 9:25:00 PM	KG

Lab ID: 1609583-023 **Client Sample ID:** Rm 22/21 North Faucet **Collection Date:** 9/12/2016 4:42:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0462	0.0200	0.00800	*	mg/L	9/19/2016 11:20:05 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1609583
CLIENT: Greater Albany Public Schools
Project: North Albany Middle
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609583-024 **Client Sample ID:** Rm 22/21 South Faucet **Collection Date:** 9/12/2016 4:43:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.261	0.0200	0.0400	*	mg/L	9/19/2016 11:20:05 AM	KG

Lab ID: 1609583-025 **Client Sample ID:** Rm 21 Faucet 2 **Collection Date:** 9/12/2016 4:44:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0109	0.0200	0.00200		mg/L	9/24/2016 9:25:00 PM	KG

Lab ID: 1609583-026 **Client Sample ID:** Rm 21 Faucet 3 **Collection Date:** 9/12/2016 4:44:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00595	0.0200	0.00200		mg/L	9/24/2016 9:25:00 PM	KG

Lab ID: 1609583-027 **Client Sample ID:** Rm 21 Faucet 4 **Collection Date:** 9/12/2016 4:45:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00853	0.0200	0.00200		mg/L	9/19/2016 11:20:05 AM	KG

Lab ID: 1609583-028 **Client Sample ID:** Rm 21 Faucet 5 **Collection Date:** 9/12/2016 4:46:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00538	0.0200	0.00200		mg/L	9/24/2016 9:25:00 PM	KG

Lab ID: 1609583-029 **Client Sample ID:** Rm 21 Faucet 6 **Collection Date:** 9/12/2016 4:46:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00734	0.0200	0.00200		mg/L	9/24/2016 9:25:00 PM	KG

Lab ID: 1609583-030 **Client Sample ID:** Rm 20 Faucet 1 **Collection Date:** 9/12/2016 4:47:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00749	0.0200	0.00200		mg/L	9/24/2016 9:25:00 PM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported 9/27/2016

WO#: 1609583
CLIENT: Greater Albany Public Schools
Project: North Albany Middle
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609583-031 **Client Sample ID:** Rm 19 Faucet **Collection Date:** 9/12/2016 4:49:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0808	0.0200	0.0200	*	mg/L	9/19/2016 11:20:05 AM	KG

Lab ID: 1609583-032 **Client Sample ID:** Rm 18 Faucet **Collection Date:** 9/12/2016 4:48:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0122	0.0200	0.00200		mg/L	9/24/2016 9:25:00 PM	KG

Lab ID: 1609583-033 **Client Sample ID:** Rm 31/32 Faucet **Collection Date:** 9/12/2016 4:32:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00489	0.0200	0.00200		mg/L	9/24/2016 9:25:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1609583
 27-Sep-16

Client: Greater Albany Public Schools
Project: North Albany Middle

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1609583-001A	Art West Faucet	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1609583-002A	Art Middle Faucet			Lead	A
	1609583-003A	Art East Faucet			Lead	A
	1609583-004A	Rm 27 Faucet			Lead	A
	1609583-005A	Rm 26 Faucet			Lead	A
	1609583-006A	Rm 32 Faucet 1			Lead	A
	1609583-007A	Rm 32 Faucet 3			Lead	A
	1609583-008A	Rm 32 Faucet 4			Lead	A
	1609583-009A	Rm 32 Faucet 5			Lead	A
	1609583-010A	Rm 32 Faucet 6			Lead	A
	1609583-011A	Rm 31 Faucet 1			Lead	A
	1609583-012A	Rm 31 Faucet 3			Lead	A
	1609583-013A	Rm 31 Faucet 4			Lead	A
	1609583-014A	Rm 30 Faucet			Lead	A
	1609583-015A	Rm 11 Faucet			Lead	A
	1609583-016A	Rm 13 Faucet			Lead	A
	1609583-017A	Rm 1 Faucet			Lead	A
	1609583-018A	Rm 22 Faucet 2			Lead	A
	1609583-019A	Rm 22 Faucet 3			Lead	A
	1609583-020A	Rm 22 Faucet 4			Lead	A
	1609583-021A	Rm 22 Faucet 5			Lead	A
	1609583-022A	Rm 22 Faucet 6			Lead	A
	1609583-023A	Rm 22/21 North Faucet			Lead	A
	1609583-024A	Rm 22/21 South Faucet			Lead	A
	1609583-025A	Rm 21 Faucet 2			Lead	A
	1609583-026A	Rm 21 Faucet 3			Lead	A
	1609583-027A	Rm 21 Faucet 4			Lead	A
	1609583-028A	Rm 21 Faucet 5			Lead	A
	1609583-029A	Rm 21 Faucet 6			Lead	A
	1609583-030A	Rm 20 Faucet 1			Lead	A

ORELAP A Accredited

ACCRED



Delivering more than just test results

ALG ORELAP ID #OR100012

361 West 5th Ave
Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 1609583

27-Sep-16

Client: Greater Albany Public Schools

Project: North Albany Middle

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1609583-031A	Rm 19 Faucet	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1609583-032A	Rm 18 Faucet			Lead	A
	1609583-033A	Rm 31/32 Faucet			Lead	A

ORELAP A Accredited

ACCRED

Original #1609583# v1

Page 9 of 11



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1609583

Date: 9/27/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- A Accredited by ORELAP
- C Value is below Minimum Compound Limit.
- E Value above quantitation range
- H Holding times for preparation or analysis exceeded
- LOD Limit of Detection
- MCL Maximum Contaminant Level
- NAR See note in Case Narrative
- ND Not Detected at the Reporting Limit
- PL Permit Limit
- R RPD outside accepted recovery limits
- RL Reporting Detection Limit
- U Samples with CalcVal < MDL
- W Sample container temperature is out of limit as specified at testcode

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: Doug Pigman	Client: Greater Albany Public Schools
Phone: 541-967-4513	Address: 3610 Grand Prairie
Email: doug.pigman@albany.k12.or.us	City, State, Zip: Albany, OR 97322
Client Project: North Albany Middle	Sampler: Print Jessica Dilbone
	Sampler: Signature Jessica Dilbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
	DW/Grab			Lead	P	1			
Art West Faucet	DW/Grab	9-12-16	4:19a	Lead	P	1			001
Art Middle Faucet	DW/Grab	9-12	4:19a	Lead	P	1			002
Art East Faucet	DW/Grab	9-12	4:20a	Lead	P	1			003
Rm 27 Faucet	DW/Grab	9-12	4:20a	Lead	P	1			004
Rm 26 Faucet	DW/Grab	9-12	4:19a	Lead	P	1			005
Rm 32 Faucet 1	DW/Grab	9-12	4:25a	Lead	P	1			006
Rm 32 Faucet 3	DW/Grab	9-12	4:25a	Lead	P	1			007
Rm 32 Faucet 4	DW/Grab	9-12	4:26a	Lead	P	1			008
Rm 32 Faucet 5	DW/Grab	9-12	4:27a	Lead	P	1			009

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG Courier	Refrigerated: no
--	------------------------------------	----------------------------

Relinquished by: Jessica Dilbone	Date	Time	Received by:	Date	Time
	9-13-16	1358			
Relinquished by:	Date	Time	Received by:	Date	Time
				9/13/16	1358
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
	9/13/16	1601		9/13/16	1601

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: Doug Pigman	Client: Greater Albany Public Schools
Phone: 541-967-4513	Address: 3610 Grand Prairie
Email: doug.pigman@albany.k12.or.us	City, State, Zip: Albany, OR 97322
Client Project: North Albany Middle	Sampler: Print Jessica Dilbone
	Sampler: Signature Jessica Dilbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 32 Faucet 6	DW/Grab	9-12-16	4:27a	Lead	P	1			010
Rm 31 Faucet 1	DW/Grab	9-12	4:28a	Lead	P	1			011
Rm 31 Faucet 3	DW/Grab	9-12	4:29a	Lead	P	1			012
Rm 31 Faucet 4	DW/Grab	9-12	4:29a	Lead	P	1			013
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
Rm 30 Faucet	DW/Grab	9-12	4:31a	Lead	P	1			014
Rm 11 Faucet	DW/Grab	9-12	4:34a	Lead	P	1			015
Rm 13 Faucet	DW/Grab	9-12	4:35a	Lead	P	1			016
Rm 1 Faucet	DW/Grab	9-12	4:38a	Lead	P	1			017

Notes:	Preservation Check																																																							
	<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Lab ID</th> <th>Date/Time</th> <th>Pre-Preserved</th> <th>pH</th> <th>Tech</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	Lab ID	Date/Time	Pre-Preserved	pH	Tech																																																		
Lab ID	Date/Time	Pre-Preserved	pH	Tech																																																				

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
<input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	ALG Courier	NO

Relinquished by: Jessica Dilbone	Date 9-13-16	Time 1358	Received by: <i>[Signature]</i>	Date	Time
Relinquished by:	Date	Time	Received by: <i>[Signature]</i>	9/13/16	1358
Relinquished by: <i>[Signature]</i>	9/13/16	1601	Received by Laboratory: <i>[Signature]</i>	9/13/16	1605 1610

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivery more than
just test results

CHAIN OF CUSTODY

Attention: Doug Pigman	Client: Greater Albany Public Schools
Phone: 541-967-4513	Address: 3610 Grand Prairie
Email: doug.pigman@albany.k12.or.us	City, State, Zip: Albany, OR 97322
Client Project: North Albany Middle	Sampler: Print Jessica Dilbone
	Sampler: Signature Jessica Dilbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 22 Faucet 2	DW/Grab	9-12-16	4:40a	Lead	P	1			018
Rm 22 Faucet 3	DW/Grab	9-12	4:40a	Lead	P	1			019
Rm 22 Faucet 4	DW/Grab	9-12	4:41a	Lead	P	1			020
Rm 22 Faucet 5	DW/Grab	9-12	4:41a	Lead	P	1			021
Rm 22 Faucet 6	DW/Grab	9-12	4:42a	Lead	P	1			022
Rm 22/21 North Faucet	DW/Grab	9-12	4:42a	Lead	P	1			023
Rm 22/21 South Faucet	DW/Grab	9-12	4:43a	Lead	P	1			024
Rm 21 Faucet 2	DW/Grab	9-12	4:44a	Lead	P	1			025
Rm 21 Faucet 3	DW/Grab	9-12	4:44a	Lead	P	1			026
Rm 21 Faucet 4	DW/Grab	9-12	4:45a	Lead	P	1			027

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG Courier	Refrigerated NO
--	------------------------------------	---------------------------

Relinquished by: Jessica Dilbone	Date	Time	Received by:	Date	Time
	9-13-16	1358			
Relinquished by:	Date	Time	Received by:	Date	Time
			Joh. [Signature]	9/13/16	1358
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
Joh. [Signature]	9/13/16	1601	[Signature]	9/13/16	1605

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: Doug Pigman	Client: Greater Albany Public Schools
Phone: 541-967-4513	Address: 3610 Grand Prairie
Email: doug.pigman@albany.k12.or.us	City, State, Zip: Albany, OR 97322
Client Project: North Albany Middle	Sampler: Print Jessica Dilbone
	Sampler: Signature Jessica Dilbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 21 Faucet 5	DW/Grab	9-12-16	4:46a	Lead	P	1			028
Rm 21 Faucet 6	DW/Grab	9-12	4:46a	Lead	P	1			029
Rm 20 Faucet 1	DW/Grab	9-12	4:47a	Lead	P	1			030
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
Rm 19 Faucet	DW/Grab	9-12	4:49a	Lead	P	1			031
Rm 18 Faucet	DW/Grab	9-12	4:48a	Lead	P	1			032

Notes:
 [Room 31/32 DW/Grab - 033
 not on CoC]
 9/12 032
 9/16 collection date time for -033 per phone w/
 Karri

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG Carrier	Refrigerated NO
--	------------------------------------	---------------------------

Relinquished by: Jessica Dilbone	Date	Time	Received by:	Date	Time
	9-13-16	1358			
Relinquished by:	Date	Time	Received by:	Date	Time
					9/13/16
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
	9/13/16	1601			9/13/16