



*Delivering more than
just test results*

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

December 07, 2016

Doug Pigman
Greater Albany Public Schools
3610 Grand Prairie
Albany, OR 97322
TEL: (541) 967-4513
FAX

RE: SAHS Retest

Order No.: 1611982

Dear Doug Pigman:

Analytical Laboratory Group received 16 sample(s) on 11/22/2016 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 1611982

Date: 12/7/2016

CLIENT: Greater Albany Public Schools

Project: SAHS Retest

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

WO#: 1611982
CLIENT: Greater Albany Public Schools
Project: SAHS Retest
PWS Number:
Sample Source:

Received Date: 11/22/2016 3:00:00 PM
Sampler Name: Kelsey O'Connell
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0200	0.0200	0.00200		mg/L	12/2/2016 9:23:00 AM	PG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0268	0.0200	0.00400	*	mg/L	12/2/2016 9:23:00 AM	PG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00652	0.0200	0.00200		mg/L	12/5/2016 3:00:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0780	0.0200	0.0200	*	mg/L	12/5/2016 3:00:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0173	0.0200	0.00200		mg/L	12/5/2016 3:00:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0910	0.0200	0.0200	*	mg/L	12/5/2016 3:00:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.237	0.0200	0.0400	*	mg/L	12/6/2016 5:11:00 PM	PG

Lab ID:	Client Sample ID			Collection Date:				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00519	0.0200	0.00200		mg/L	12/5/2016 3:00:00 PM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1611982
CLIENT: Greater Albany Public Schools
Project: SAHS Retest
PWS Number:
Sample Source:

Received Date: 11/22/2016 3:00:00 PM
Sampler Name: Kelsey O'Connell
Matrix: Drinking Water
Sample Type:

Lab ID: 1611982-009 **Client Sample ID:** Rm 209 - Faucet 6 **Collection Date:** 11/22/2016 6:27:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0392	0.0200	0.00800	*	mg/L	12/5/2016 3:00:00 PM	PG

Lab ID: 1611982-010 **Client Sample ID:** Rm 217 - Faucet 2 **Collection Date:** 11/22/2016 6:30:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0774	0.0200	0.00800	*	mg/L	12/5/2016 3:00:00 PM	PG

Lab ID: 1611982-011 **Client Sample ID:** Rm 217 - Faucet 1 **Collection Date:** 11/22/2016 6:30:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.181	0.0200	0.0200	*	mg/L	12/5/2016 3:00:00 PM	PG

Lab ID: 1611982-012 **Client Sample ID:** Rm 217 - Faucet 5 **Collection Date:** 11/22/2016 6:31:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0115	0.0200	0.00200		mg/L	12/5/2016 3:00:00 PM	PG

Lab ID: 1611982-013 **Client Sample ID:** Rm 308 - Faucet 1 **Collection Date:** 11/22/2016 6:12:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0164	0.0200	0.00400		mg/L	12/5/2016 3:00:00 PM	PG

Lab ID: 1611982-014 **Client Sample ID:** Rm 307 - Faucet 2 **Collection Date:** 11/22/2016 6:09:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00539	0.0200	0.00200		mg/L	12/5/2016 3:00:00 PM	PG

Lab ID: 1611982-015 **Client Sample ID:** Rm 307 - Faucet 3 **Collection Date:** 11/22/2016 6:09:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0121	0.0200	0.00200		mg/L	12/5/2016 3:00:00 PM	PG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported **12/7/2016**

WO#: 1611982
CLIENT: Greater Albany Public Schools
Project: SAHS Retest
PWS Number:
Sample Source:

Received Date: 11/22/2016 3:00:00 PM
Sampler Name: Kelsey O'Connell
Matrix: Drinking Water
Sample Type:

Lab ID: 1611982-016 **Client Sample ID:** Rm 307 - Faucet 4 **Collection Date:** 11/22/2016 6:08:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00954	0.0200	0.00200		mg/L	12/5/2016 3:00:00 PM	PG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1611982

Date: 12/7/2016

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

**Accreditation Program
 Analytes Report**

WO#: 1611982
 07-Dec-16

Client: Greater Albany Public Schools
Project: SAHS Retest

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1611982-001A	Rm 211 - Faucet 1	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1611982-002A	Rm 211 - Faucet 6			Lead	A
	1611982-003A	Rm 215 - Faucet 2			Lead	A
	1611982-004A	Rm 216 - Faucet 1			Lead	A
	1611982-005A	Rm 210 - Faucet 2			Lead	A
	1611982-006A	Rm 209 - Faucet 1			Lead	A
	1611982-007A	Rm 209 - Faucet 2			Lead	A
	1611982-008A	Rm 209 - Faucet 4			Lead	A
	1611982-009A	Rm 209 - Faucet 6			Lead	A
	1611982-010A	Rm 217 - Faucet 2			Lead	A
	1611982-011A	Rm 217 - Faucet 1			Lead	A
	1611982-012A	Rm 217 - Faucet 5			Lead	A
	1611982-013A	Rm 308 - Faucet 1			Lead	A
	1611982-014A	Rm 307 - Faucet 2			Lead	A
	1611982-015A	Rm 307 - Faucet 3			Lead	A
	1611982-016A	Rm 307 - Faucet 4			Lead	A

ORELAP A Accredited

ACCRED

4

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Deliv: just 1 NPUC

CHAIN OF CUSTODY

Attention: Doug Pigman		Client: Greater Albany Public Schools	
Phone: 541-967-4513		Address: 3610 Grand Prairie	
Email: doug.pigman@albany.k12.or.us		City, State, Zip: Albany, OR 97322	
Client Project: SAHS Retest		Sampler: Print kelsey O'Connell	Sampler: Signature <i>[Signature]</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 211-Faucet 1	DW/Grab	11/22	6:18	Lead	P	1			001A
Rm 211-Faucet 6	DW/Grab	11/22	6:18	Lead	P	1			002A
Rm 215-Faucet 2	DW/Grab	11/22	6:16	Lead	P	1			003A
Rm 216-Faucet 1	DW/Grab	11/22	6:24	Lead	P	1			004A
Rm 210-Faucet 2	DW/Grab	11/22	6:25	Lead	P	1			005A
Rm 209-Faucet 1	DW/Grab	11/22	6:26	Lead	P	1			006A
Rm 209-Faucet 2	DW/Grab	11/22	6:26	Lead	P	1			007A
Rm 209-Faucet 4	DW/Grab	11/22	6:27	Lead	P	1			008A
Rm 209-Faucet 6	DW/Grab	11/22	6:27	Lead	P	1			009A
Rm 217-Faucet 2	DW/Grab	11/22	6:30	Lead	P	1			010A

Notes:
 Rm 215 - Faucet 2 (bottle says faucet ¹) ~~2~~ on 11/22/16
 Faucet 2 is correct

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG Courier	Refrigerated: ice
--	------------------------------------	-----------------------------

Relinquished by: <i>Kami O'Connell</i>	Date 	Time 	Received by: <i>Cathie Thomas</i>	Date 	Time
Relinquished by: <i>Cathie Thomas</i>	Date 11/22/16	Time 1300	Received by: <i>[Signature]</i>	Date 11/22/16	Time 1300
Relinquished by: <i>[Signature]</i>	Date 11/22/16	Time 1500	Received by Laboratory: <i>[Signature]</i>	Date 11/22/16	Time 1500

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering just test it **NPUC**

CHAIN OF CUSTODY

Attention: Doug Pigman	Client: Greater Albany Public Schools
Phone: 541-967-4513	Address: 3610 Grand Prairie
Email: doug.pigman@albany.k12.or.us	City, State, Zip: Albany, OR 97322
Client Project: SAHS Retest	Sampler: Print Kelsey O'Connell
	Sampler: Signature <i>Kelsey O'Connell</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 217 - Faucet 1	DW/Grab	11/22	6:30	Lead	P	1			011A
Rm 217 - Faucet 5	DW/Grab	11/22	6:31	Lead	P	1			012A
Rm 308 - Faucet 1	DW/Grab	11/22	6:12	Lead	P	1			013A
Rm 307 - Faucet 2	DW/Grab	11/22	6:09	Lead	P	1			014A
Rm 307 - Faucet 3	DW/Grab	11/22	6:09	Lead	P	1			015A
Rm 307 - Faucet 4	DW/Grab	11/22	6:08	Lead	P	1			016A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG Courier	Refrigerated ice
--	------------------------------------	----------------------------

Relinquished by: <i>Kelsey O'Connell</i>	Date	Time	Received by: <i>Cathrin Thomas</i>	Date	Time
Relinquished by: <i>Cathrin Thomas</i>	11/22/16	1300	Received by: <i>John Jr</i>	11/22/16	1300
Relinquished by: <i>John Jr</i>	11/22/16	1500	Received by Laboratory: <i>[Signature]</i>	11/22/16	1500