



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

September 26, 2016

Doug Pigman
Greater Albany Public Schools
3610 Grand Prairie
Albany, OR 97322
TEL: (541) 967-4513
FAX

RE: South Albany Initial Round 2

Order No.: 1609584

Dear Doug Pigman:

Analytical Laboratory Group received 39 sample(s) on 9/13/2016 for the analyses presented in the following report.

Kimberly Reever Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 1609584

Date: 9/26/2016

CLIENT: Greater Albany Public Schools

Project: South Albany Initial Round 2

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

WO#: 1609584
CLIENT: Greater Albany Public Schools
Project: South Albany Initial Round 2
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609584-001 **Client Sample ID:** 303 West Faucet **Collection Date:** 9/12/2016 7:22:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00267	0.0200	0.00200		mg/L	9/25/2016 11:08:00 AM	KG

Lab ID: 1609584-002 **Client Sample ID:** 303 East Faucet **Collection Date:** 9/12/2016 7:23:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00472	0.0200	0.00200		mg/L	9/25/2016 11:08:00 AM	KG

Lab ID: 1609584-003 **Client Sample ID:** 308 NW Faucet **Collection Date:** 9/12/2016 7:23:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0105	0.0200	0.00200		mg/L	9/25/2016 11:08:00 AM	KG

Lab ID: 1609584-004 **Client Sample ID:** 308 SW Faucet **Collection Date:** 9/12/2016 7:22:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0451	0.0200	0.00800	*	mg/L	9/19/2016 11:20:05 AM	KG

Lab ID: 1609584-005 **Client Sample ID:** 309 NE Faucet **Collection Date:** 9/12/2016 7:24:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00335	0.0200	0.00200		mg/L	9/25/2016 11:08:00 AM	KG

Lab ID: 1609584-006 **Client Sample ID:** 309 SE Faucet **Collection Date:** 9/12/2016 7:24:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00743	0.0200	0.00200		mg/L	9/25/2016 11:08:00 AM	KG

Lab ID: 1609584-007 **Client Sample ID:** 309 NW Faucet **Collection Date:** 9/12/2016 7:24:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00593	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-008 **Client Sample ID:** 309 SW Faucet **Collection Date:** 9/12/2016 7:25:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00737	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1609584
CLIENT: Greater Albany Public Schools
Project: South Albany Initial Round 2
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609584-009 **Client Sample ID:** 301 Faucet **Collection Date:** 9/12/2016 7:25:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-010 **Client Sample ID:** 214 Faucet 1 **Collection Date:** 9/12/2016 6:48:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-011 **Client Sample ID:** 214 Faucet 2 **Collection Date:** 9/12/2016 6:48:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00360	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-012 **Client Sample ID:** 214 Faucet 3 **Collection Date:** 9/12/2016 6:49:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00862	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-013 **Client Sample ID:** 214 Faucet 4 **Collection Date:** 9/12/2016 6:49:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-014 **Client Sample ID:** 214 Faucet 5 **Collection Date:** 9/12/2016 6:49:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00354	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-015 **Client Sample ID:** 214 Faucet 6 **Collection Date:** 9/12/2016 6:50:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00477	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



WO#: 1609584
CLIENT: Greater Albany Public Schools
Project: South Albany Initial Round 2
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609584-016 **Client Sample ID:** 214 Faucet 7 **Collection Date:** 9/12/2016 6:50:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00911	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-017 **Client Sample ID:** 212 Faucet 1 **Collection Date:** 9/12/2016 6:51:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00411	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-018 **Client Sample ID:** 212 Faucet 2 **Collection Date:** 9/12/2016 6:52:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00239	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-019 **Client Sample ID:** 212 Faucet 3 **Collection Date:** 9/12/2016 6:52:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00458	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-020 **Client Sample ID:** 212 Faucet 4 **Collection Date:** 9/12/2016 6:53:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-021 **Client Sample ID:** 212 Faucet 5 **Collection Date:** 9/12/2016 6:53:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00274	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-022 **Client Sample ID:** 212 Faucet 6 **Collection Date:** 9/12/2016 6:54:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-023 **Client Sample ID:** 212 Faucet 7 **Collection Date:** 9/12/2016 6:54:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



WO#: 1609584
CLIENT: Greater Albany Public Schools
Project: South Albany Initial Round 2
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609584-024 **Client Sample ID:** 211 Faucet 1 **Collection Date:** 9/12/2016 6:55:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0232	0.0200	0.00400	*	mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-025 **Client Sample ID:** 211 Faucet 2 **Collection Date:** 9/12/2016 6:56:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0194	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-026 **Client Sample ID:** 211 Faucet 3 **Collection Date:** 9/12/2016 6:56:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0102	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-027 **Client Sample ID:** 211 Faucet 4 **Collection Date:** 9/12/2016 6:57:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0107	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-028 **Client Sample ID:** 211 Faucet 5 **Collection Date:** 9/12/2016 6:57:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0167	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-029 **Client Sample ID:** 211 Faucet 6 **Collection Date:** 9/12/2016 6:58:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0282	0.0200	0.00400	*	mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-030 **Client Sample ID:** 215 Faucet 1 **Collection Date:** 9/12/2016 7:00:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0126	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1609584
CLIENT: Greater Albany Public Schools
Project: South Albany Initial Round 2
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609584-031 **Client Sample ID:** 215 Faucet 2 **Collection Date:** 9/12/2016 7:01:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0384	0.0200	0.00800	*	mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-032 **Client Sample ID:** 215 Faucet 3 **Collection Date:** 9/12/2016 7:01:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00788	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-033 **Client Sample ID:** 215 Faucet 4 **Collection Date:** 9/12/2016 7:02:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00673	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-034 **Client Sample ID:** 215 Faucet 5 **Collection Date:** 9/12/2016 7:03:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0144	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-035 **Client Sample ID:** 215 Faucet 6 **Collection Date:** 9/12/2016 7:03:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0132	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-036 **Client Sample ID:** 210 Faucet 1 **Collection Date:** 9/12/2016 7:04:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0183	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-037 **Client Sample ID:** 210 Faucet 2 **Collection Date:** 9/12/2016 7:04:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0211	0.0200	0.00400	*	mg/L	9/26/2016 7:22:00 AM	PG

Lab ID: 1609584-038 **Client Sample ID:** 210 Faucet 3 **Collection Date:** 9/12/2016 7:05:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00485	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported **9/26/2016**

WO#: 1609584
CLIENT: Greater Albany Public Schools
Project: South Albany Initial Round 2
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609584-039	Client Sample ID 210 Faucet 4	Collection Date: 9/12/2016 7:06:00 AM						
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0179	0.0200	0.00200		mg/L	9/26/2016 7:22:00 AM	PG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1609584
 26-Sep-16

Client: Greater Albany Public Schools
Project: South Albany Initial Round 2

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1609584-001A	303 West Faucet	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1609584-002A	303 East Faucet			Lead	A
	1609584-003A	308 NW Faucet			Lead	A
	1609584-004A	308 SW Faucet			Lead	A
	1609584-005A	309 NE Faucet			Lead	A
	1609584-006A	309 SE Faucet			Lead	A
	1609584-007A	309 NW Faucet			Lead	A
	1609584-008A	309 SW Faucet			Lead	A
	1609584-009A	301 Faucet			Lead	A
	1609584-010A	214 Faucet 1			Lead	A
	1609584-011A	214 Faucet 2			Lead	A
	1609584-012A	214 Faucet 3			Lead	A
	1609584-013A	214 Faucet 4			Lead	A
	1609584-014A	214 Faucet 5			Lead	A
	1609584-015A	214 Faucet 6			Lead	A
	1609584-016A	214 Faucet 7			Lead	A
	1609584-017A	212 Faucet 1			Lead	A
	1609584-018A	212 Faucet 2			Lead	A
	1609584-019A	212 Faucet 3			Lead	A
	1609584-020A	212 Faucet 4			Lead	A
	1609584-021A	212 Faucet 5			Lead	A
	1609584-022A	212 Faucet 6			Lead	A
	1609584-023A	212 Faucet 7			Lead	A
	1609584-024A	211 Faucet 1			Lead	A
	1609584-025A	211 Faucet 2			Lead	A
	1609584-026A	211 Faucet 3			Lead	A
	1609584-027A	211 Faucet 4			Lead	A
	1609584-028A	211 Faucet 5			Lead	A
	1609584-029A	211 Faucet 6			Lead	A
	1609584-030A	215 Faucet 1			Lead	A
	1609584-031A	215 Faucet 2			Lead	A

ACCRED

ORELAP A Accredited



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

**Accreditation Program
 Analytes Report**
 WO#: 1609584
 26-Sep-16

Client: Greater Albany Public Schools
Project: South Albany Initial Round 2

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1609584-032A	215 Faucet 3	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1609584-033A	215 Faucet 4			Lead	A
	1609584-034A	215 Faucet 5			Lead	A
	1609584-035A	215 Faucet 6			Lead	A
	1609584-036A	210 Faucet 1			Lead	A
	1609584-037A	210 Faucet 2			Lead	A
	1609584-038A	210 Faucet 3			Lead	A
	1609584-039A	210 Faucet 4			Lead	A

ORELAP A Accredited

ACCRED



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1609584

Date: 9/26/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported

Definition Base

WO#: 1609584
Date: 9/26/2016

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivery more
just test results

NPUC

CHAIN OF CUSTODY

Attention: Doug Pigman	Client: Greater Albany Public Schools
Phone: 541-967-4513	Address: 3610 Grand Prairie
Email: doug.pigman@albany.k12.or.us	City, State, Zip: Albany, OR 97322
Client Project: South Albany Initial Round 2	Sampler: Print Jessica Dilbone
	Sampler: Signature Jessica Dilbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
	DW/Grab			Lead	P	1			
303 West Faucet	DW/Grab	9-12	7:22a	Lead	P	1			001A
303 East Faucet	DW/Grab	9-12	7:23a	Lead	P	1			002A
308 NW Faucet	DW/Grab	9-12	7:23a	Lead	P	1			003A
308 SW Faucet	DW/Grab	9-12	7:22a	Lead	P	1			004A
309 NE Faucet	DW/Grab	9-12	7:24a	Lead	P	1			005A
309 SE Faucet	DW/Grab	9-12	7:24a	Lead	P	1			006A
309 NW Faucet	DW/Grab	9-12	7:24a	Lead	P	1			007A
309 SW Faucet	DW/Grab	9-12	7:25a	Lead	P	1			008A
301 Faucet	DW/Grab	9-12	7:25a	Lead	P	1			009A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		Refrigerated	
<input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____		ALG Courier		NA	
Relinquished by:		Received by:		Date	
Jessica Dilbone					
Relinquished by:		Received by:		Date	
		Josh [Signature]		9/13/16	
Relinquished by:		Received by Laboratory:		Date	
Josh [Signature]				9/13/16	
Date		Time		Time	
9/13/16		1601		1601	

CO

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results.

NPUC

CHAIN OF CUSTODY

Attention: Doug Pigman	Client: Greater Albany Public Schools
Phone: 541-967-4513	Address: 3610 Grand Prairie
Email: doug.pigman@albany.k12.or.us	City, State, Zip: Albany, OR 97322
Client Project: South Albany Initial Round 2	Sampler: Print Jessica Dillbone
	Sampler: Signature Jessica Dillbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
214 Faucet 1	DW/Grab	9-12-16	6:48a	Lead	P	1			010A
214 Faucet 2	DW/Grab	9-12	6:48a	Lead	P	1			011A
214 Faucet 3	DW/Grab	9-12	6:49a	Lead	P	1			012A
214 Faucet 4	DW/Grab	9-12	6:49a	Lead	P	1			013A
214 Faucet 5	DW/Grab	9-12	6:49a	Lead	P	1			014A
214 Faucet 6	DW/Grab	9-12	6:50a	Lead	P	1			015A
214 Faucet 7	DW/Grab	9-12	6:50a	Lead	P	1			016A
212 Faucet 1	DW/Grab	9-12	6:51a	Lead	P	1			017A
212 Faucet 2	DW/Grab	9-12	6:52a	Lead	P	1			018A
212 Faucet 3	DW/Grab	9-12	6:52a	Lead	P	1			019A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG Courier	Refrigerated: NA
--	------------------------------------	----------------------------

Relinquished by: Jessica Dillbone	Date 9-13-16	Time 1358	Received by:	Date	Time
Relinquished by:	Date	Time	Received by: Josh J	9/13/16	1358
Relinquished by: Josh J	Date 9/13/16	Time 1601	Received by Laboratory: [Signature]	Date 9/13/16	Time 1601

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more
just test results

CO

NPUC

CHAIN OF CUSTODY

Attention: Doug Pigman	Client: Greater Albany Public Schools
Phone: 541-967-4513	Address: 3610 Grand Prairie
Email: doug.pigman@albany.k12.or.us	City, State, Zip: Albany, OR 97322
Client Project: South Albany Initial Round 2	Sampler: Print Jessica Dilbone
	Sampler: Signature Jessica Dilbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
212 Faucet 4	DW/Grab	9-12-16	6:53a	Lead	P	1			020A
212 Faucet 5	DW/Grab	9-12	6:53a	Lead	P	1			021A
212 Faucet 6	DW/Grab	9-12	6:54a	Lead	P	1			022A
212 Faucet 7	DW/Grab	9-12	6:54a	Lead	P	1			023A
211 Faucet 1	DW/Grab	9-12	6:55a	Lead	P	1			024A
211 Faucet 2	DW/Grab	9-12	6:56a	Lead	P	1			025A
211 Faucet 3	DW/Grab	9-12	6:56a	Lead	P	1			026A
211 Faucet 4	DW/Grab	9-12	6:57a	Lead	P	1			027A
211 Faucet 5	DW/Grab	9-12	6:57a	Lead	P	1			028A
211 Faucet 6	DW/Grab	9-12	6:58a	Lead	P	1			029A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
<input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	ALG Courier	NA

Relinquished by: Jessica Dilbone	Date 9-13-16 Time 1358	Received by:	Date	Time
Relinquished by:	Date	John Jr	9/13/16	1358
Relinquished by: John Jr	Date 9/13/16 Time 1601	Received by Laboratory:	Date 9/13/16	Time 1601

CO

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivery more!
 just test result

NPUC

CHAIN OF CUSTODY

Attention: Doug Pigman	Client: Greater Albany Public Schools
Phone: 541-967-4513	Address: 3610 Grand Prairie
Email: doug.pigman@albany.k12.or.us	City, State, Zip: Albany, OR 97322
Client Project: South Albany Initial Round 2	Sampler: Print Jessica Dillbone
	Sampler: Signature Jessica Dillbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
215 Faucet 1	DW/Grab	9-12-16	7:00a	Lead	P	1			030A
215 Faucet 2	DW/Grab	9-12	7:01a	Lead	P	1			031A
215 Faucet 3	DW/Grab	9-12	7:01a	Lead	P	1			032A
215 Faucet 4	DW/Grab	9-12	7:02a	Lead	P	1			033A
215 Faucet 5	DW/Grab	9-12	7:03a	Lead	P	1			034A
215 Faucet 6	DW/Grab	9-12	7:03a	Lead	P	1			035A
210 Faucet 1	DW/Grab	9-12	7:04a	Lead	P	1			036A
210 Faucet 2	DW/Grab	9-12	7:04a	Lead	P	1			037A
210 Faucet 3	DW/Grab	9-12	7:05a	Lead	P	1			038A
210 Faucet 4	DW/Grab	9-12	7:06a	Lead	P	1			039A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG Carrier	Refrigerated NA
Relinquished by: Jessica Dillbone	Date 9-13-16 Time 1358	Received by:
Relinquished by:	Date Time	Date 9/13/16 Time 1358
Relinquished by: Josh Jr	Date 9/13/16 Time 1601	Received by Laboratory: 9/13/16 1601