



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

August 15, 2016

Doug Pigman
Greater Albany Public Schools
3610 Grand Prairie
Albany, OR 97322
TEL: (541) 967-4513
FAX

RE: Sunrise

Order No.: 1607508

Dear Doug Pigman:

Analytical Laboratory Group received 45 sample(s) on 7/12/2016 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 1607508

Date: 8/15/2016

CLIENT: Greater Albany Public Schools

Project: Sunrise

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

WO#: 1607508
CLIENT: Greater Albany Public Schools
Project: Sunrise
PWS Number:
Sample Source:

Received Date: 7/12/2016 3:00:00 PM
Sampler Name: Kelsey O'Connell/ Stephanie
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	Rm 1 Fountain		Collection Date: 7/8/2016 3:42:00 PM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0202	0.0200	0.00400	*	mg/L	8/14/2016 7:38:00 AM	KG

Lab ID:	Client Sample ID	Rm 1 Bathroom Sink		Collection Date: 7/8/2016 3:42:00 PM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00775	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	KG

Lab ID:	Client Sample ID	Rm 1 Sink		Collection Date: 7/8/2016 3:42:00 PM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00252	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	KG

Lab ID:	Client Sample ID	Rm 2 Fountain		Collection Date: 7/8/2016 3:39:00 PM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00601	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	KG

Lab ID:	Client Sample ID	Rm 2 Bathroom Sink		Collection Date: 7/8/2016 3:39:00 PM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00736	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	KG

Lab ID:	Client Sample ID	Rm 2 Sink		Collection Date: 7/8/2016 3:39:00 PM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0255	0.0200	0.00400	*	mg/L	8/14/2016 7:38:00 AM	KG

Lab ID:	Client Sample ID	Rm 3 Sink		Collection Date: 7/8/2016 3:38:00 PM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00710	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	KG

Lab ID:	Client Sample ID	Rm 4 Sink		Collection Date: 7/8/2016 3:37:00 PM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00601	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607508
CLIENT: Greater Albany Public Schools
Project: Sunrise
PWS Number:
Sample Source:

Received Date: 7/12/2016 3:00:00 PM
Sampler Name: Kelsey O'Connell/ Stephanie
Matrix: Drinking Water
Sample Type:

Lab ID: 1607508-009 **Client Sample ID** RM 5 Bathroom Sink **Collection Date:** 7/8/2016 3:35:00 PM
Analyses **Method** **Result** **MCL** **RL** **Qual** **Units** **Date Analyzed** **Analys**

Lead SM 3113 B 0.00757 0.0200 0.00200 mg/L 8/14/2016 7:38:00 AM KG

Lab ID: 1607508-010 **Client Sample ID** Rm 5 Sink **Collection Date:** 7/8/2016 3:35:00 PM
Analyses **Method** **Result** **MCL** **RL** **Qual** **Units** **Date Analyzed** **Analys**

Lead SM 3113 B 0.00480 0.0200 0.00200 mg/L 8/14/2016 7:38:00 AM KG

Lab ID: 1607508-011 **Client Sample ID** Rm 6 Bathroom Sink **Collection Date:** 7/8/2016 3:30:00 PM
Analyses **Method** **Result** **MCL** **RL** **Qual** **Units** **Date Analyzed** **Analys**

Lead SM 3113 B 0.00330 0.0200 0.00200 mg/L 8/14/2016 7:38:00 AM KG

Lab ID: 1607508-012 **Client Sample ID** Rm 6 Sink **Collection Date:** 7/8/2016 3:31:00 PM
Analyses **Method** **Result** **MCL** **RL** **Qual** **Units** **Date Analyzed** **Analys**

Lead SM 3113 B 0.00466 0.0200 0.00200 mg/L 8/14/2016 7:38:00 AM KG

Lab ID: 1607508-013 **Client Sample ID** Rm 7 Fountain **Collection Date:** 7/8/2016 3:25:00 PM
Analyses **Method** **Result** **MCL** **RL** **Qual** **Units** **Date Analyzed** **Analys**

Lead SM 3113 B 0.00708 0.0200 0.00200 mg/L 8/14/2016 7:38:00 AM KG

Lab ID: 1607508-014 **Client Sample ID** Rm 7 Bathroom Sink **Collection Date:** 7/8/2016 3:25:00 PM
Analyses **Method** **Result** **MCL** **RL** **Qual** **Units** **Date Analyzed** **Analys**

Lead SM 3113 B 0.00696 0.0200 0.00200 mg/L 8/14/2016 7:38:00 AM KG

Lab ID: 1607508-015 **Client Sample ID** Rm 7 Sink **Collection Date:** 7/8/2016 3:24:00 PM
Analyses **Method** **Result** **MCL** **RL** **Qual** **Units** **Date Analyzed** **Analys**

Lead SM 3113 B 0.0194 0.0200 0.00400 mg/L 8/14/2016 7:38:00 AM KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607508
CLIENT: Greater Albany Public Schools
Project: Sunrise
PWS Number:
Sample Source:

Received Date: 7/12/2016 3:00:00 PM
Sampler Name: Kelsey O'Connell/ Stephanie
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	RM	Collection Date:					
1607508-016	RM 8 Fountain		7/8/2016 3:24:00 PM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	KG

Lab ID:	Client Sample ID	RM	Collection Date:					
1607508-017	Rm 8 BR Sink		7/8/2016 3:23:00 PM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00558	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG

Lab ID:	Client Sample ID	RM	Collection Date:					
1607508-018	Rm 8 Sink		7/8/2016 3:23:00 PM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00852	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG

Lab ID:	Client Sample ID	RM	Collection Date:					
1607508-019	Rm 9 Fountain		7/8/2016 3:21:00 PM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00682	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG

Lab ID:	Client Sample ID	RM	Collection Date:					
1607508-020	Rm 9 Sink		7/8/2016 3:21:00 PM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0150	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG

Lab ID:	Client Sample ID	RM	Collection Date:					
1607508-021	Rm 13 Fountain		7/8/2016 3:56:00 PM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00477	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG

Lab ID:	Client Sample ID	RM	Collection Date:					
1607508-022	Rm 13 Sink		7/8/2016 3:56:00 PM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0241	0.0200	0.00400	*	mg/L	8/14/2016 7:38:00 AM	PG

Lab ID:	Client Sample ID	RM	Collection Date:					
1607508-023	Rm 14 Sink		7/8/2016 3:51:00 PM					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00809	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607508
CLIENT: Greater Albany Public Schools
Project: Sunrise
PWS Number:
Sample Source:

Received Date: 7/12/2016 3:00:00 PM
Sampler Name: Kelsey O'Connell/ Stephanie
Matrix: Drinking Water
Sample Type:

Lab ID: 1607508-024 **Client Sample ID:** Rm 14 Fountain **Collection Date:** 7/8/2016 3:51:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00772	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG

Lab ID: 1607508-025 **Client Sample ID:** Rm 15 Sink **Collection Date:** 7/8/2016 3:50:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00442	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG

Lab ID: 1607508-026 **Client Sample ID:** Rm 16 Sink **Collection Date:** 7/8/2016 3:49:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00657	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG

Lab ID: 1607508-027 **Client Sample ID:** Rm 17 Sink **Collection Date:** 7/8/2016 3:47:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00495	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG

Lab ID: 1607508-028 **Client Sample ID:** Rm 18 Sink **Collection Date:** 7/8/2016 3:54:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0150	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG

Lab ID: 1607508-029 **Client Sample ID:** Rm 19 Sink **Collection Date:** 7/8/2016 3:54:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00634	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG

Lab ID: 1607508-030 **Client Sample ID:** Rm 20 Sink **Collection Date:** 7/8/2016 3:54:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00537	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



WO#: 1607508
CLIENT: Greater Albany Public Schools
Project: Sunrise
PWS Number:
Sample Source:

Received Date: 7/12/2016 3:00:00 PM
Sampler Name: Kelsey O'Connell/ Stephanie
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID			Collection Date:			
1607508-031	Rm 21 Sink			7/8/2016 3:54:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	0.0109	0.0200	0.00200	mg/L	8/14/2016 7:38:00 AM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607508-032	Rm 3 Hall Fountain			7/8/2016 3:38:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	8/14/2016 7:38:00 AM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607508-033	Rm 14 Hall Fountain			7/8/2016 3:52:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	0.00681	0.0200	0.00200	mg/L	8/14/2016 7:38:00 AM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607508-034	North Dishwashing Sink			7/8/2016 4:02:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	8/14/2016 7:38:00 AM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607508-035	South Dishwashing Sink			7/8/2016 4:03:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	0.0424	0.0200	0.00800 *	mg/L	8/14/2016 7:38:00 AM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607508-036	Handwashing sink			7/8/2016 4:04:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	8/14/2016 7:38:00 AM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607508-037	Rm 34 BR Sink			7/8/2016 3:59:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	8/14/2016 7:38:00 AM	PG

Lab ID:	Client Sample ID			Collection Date:			
1607508-038	First Aid Rm Sink			7/8/2016 3:58:00 PM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	8/14/2016 7:38:00 AM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607508
CLIENT: Greater Albany Public Schools
Project: Sunrise
PWS Number:
Sample Source:

Received Date: 7/12/2016 3:00:00 PM
Sampler Name: Kelsey O'Connell/ Stephanie
Matrix: Drinking Water
Sample Type:

Lab ID: 1607508-039 **Client Sample ID:** Resource Rm Fountain **Collection Date:** 7/8/2016 3:14:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00491	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG
------	-----------	---------	--------	---------	--	------	----------------------	----

Lab ID: 1607508-040 **Client Sample ID:** Resource Rm Sink **Collection Date:** 7/8/2016 3:14:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.152	0.0200	0.0200	*	mg/L	8/14/2016 7:38:00 AM	PG
------	-----------	-------	--------	--------	---	------	----------------------	----

Lab ID: 1607508-041 **Client Sample ID:** Staff Rm Sink **Collection Date:** 7/8/2016 3:15:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG
------	-----------	----	--------	---------	--	------	----------------------	----

Lab ID: 1607508-042 **Client Sample ID:** Gym Fountain **Collection Date:** 7/8/2016 3:44:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00275	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG
------	-----------	---------	--------	---------	--	------	----------------------	----

Lab ID: 1607508-043 **Client Sample ID:** RM 10 Fountain **Collection Date:** 7/8/2016 3:19:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG
------	-----------	----	--------	---------	--	------	----------------------	----

Lab ID: 1607508-044 **Client Sample ID:** Rm 10 Sink **Collection Date:** 7/8/2016 3:20:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.0246	0.0200	0.00400	*	mg/L	8/14/2016 7:38:00 AM	PG
------	-----------	--------	--------	---------	---	------	----------------------	----

Lab ID: 1607508-045 **Client Sample ID:** Staff Room Hall Fountain **Collection Date:** 7/8/2016 3:18:00 PM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00211	0.0200	0.00200		mg/L	8/14/2016 7:38:00 AM	PG
------	-----------	---------	--------	---------	--	------	----------------------	----

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1607508
 15-Aug-16

Client: Greater Albany Public Schools
Project: Sunrise

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607508-001A	Rm 1 Fountain	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607508-002A	Rm 1 Bathroom Sink			Lead	A
	1607508-003A	Rm 1 Sink			Lead	A
	1607508-004A	Rm 2 Fountain			Lead	A
	1607508-005A	Rm 2 Bathroom Sink			Lead	A
	1607508-006A	Rm 2 Sink			Lead	A
	1607508-007A	Rm 3 Sink			Lead	A
	1607508-008A	Rm 4 Sink			Lead	A
	1607508-009A	RM 5 Bathroom Sink			Lead	A
	1607508-010A	Rm 5 Sink			Lead	A
	1607508-011A	Rm 6 Bathroom Sink			Lead	A
	1607508-012A	Rm 6 Sink			Lead	A
	1607508-013A	Rm 7 Fountain			Lead	A
	1607508-014A	Rm 7 Bathroom Sink			Lead	A
	1607508-015A	Rm 7 Sink			Lead	A
	1607508-016A	RM 8 Fountain			Lead	A
	1607508-017A	Rm 8 BR Sink			Lead	A
	1607508-018A	Rm 8 Sink			Lead	A
	1607508-019A	Rm 9 Fountain			Lead	A
	1607508-020A	Rm 9 Sink			Lead	A
	1607508-021A	Rm 13 Fountain			Lead	A
	1607508-022A	Rm 13 Sink			Lead	A
	1607508-023A	Rm 14 Sink			Lead	A
	1607508-024A	Rm 14 Fountain			Lead	A
	1607508-025A	Rm 15 Sink			Lead	A
	1607508-026A	Rm 16 Sink			Lead	A
	1607508-027A	Rm 17 Sink			Lead	A
	1607508-028A	Rm 18 Sink			Lead	A
	1607508-029A	Rm 19 Sink			Lead	A

ORELAP A Accredited

ACCRED



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1607508
 15-Aug-16

Client: Greater Albany Public Schools
Project: Sunrise

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607508-030A	Rm 20 Sink	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607508-031A	Rm 21 Sink			Lead	A
	1607508-032A	Rm 3 Hall Fountain			Lead	A
	1607508-033A	Rm 14 Hall Fountain			Lead	A
	1607508-034A	North Dishwashing Sink			Lead	A
	1607508-035A	South Dishwashing Sink			Lead	A
	1607508-036A	Handwashing sink			Lead	A
	1607508-037A	Rm 34 BR Sink			Lead	A
	1607508-038A	First Aid Rm Sink			Lead	A
	1607508-039A	Resource Rm Fountain			Lead	A
	1607508-040A	Resource Rm Sink			Lead	A
	1607508-041A	Staff Rm Sink			Lead	A
	1607508-042A	Gym Fountain			Lead	A
	1607508-043A	RM 10 Fountain			Lead	A
	1607508-044A	Rm 10 Sink			Lead	A
	1607508-045A	Staff Room Hall Fountain			Lead	A

ORELAP A Accredited

ACCRED

Original #1607508# v1



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1607508

Date: 8/15/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported

Original

Page 11 of 12



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1607508

Date: 8/15/2016

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivery in
just test res

PUC

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@alglabsinc.com</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Sunrise</u>	Sampler: <u>Print Kelsey O'Connell Stephanie Dilbone</u>
	Sampler: <u>Signature</u>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 1 fountain	DW/Grab	7-8	3:42	Lead	P	1			001A
Rm 1 Bathroom sink	DW/Grab	7-8	3:42	Lead	P	1			002A
Rm 1 sink	DW/Grab	7-8	3:42	Lead	P	1			003A
Rm 2 fountain	DW/Grab	7-8	3:39	Lead	P	1			004A
Rm 2 Bathroom sink	DW/Grab	7-8	3:39	Lead	P	1			005A
Rm 2 sink	DW/Grab	7-8	3:39	Lead	P	1			006A
Rm 3 sink	DW/Grab	7-8	3:38	Lead	P	1			007A
Rm 4 sink	DW/Grab	7-8	3:37	Lead	P	1			008A
Rm 5 Bathroom sink	DW/Grab	7-8	3:35	Lead	P	1			009A
Rm 5 sink	DW/Grab	7-8	3:35	Lead	P	1			010A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG Carrier</u>	Refrigerated <u>NA</u>			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>MF</u>	<u>7/12/16</u>	<u>1500</u>	<u>[Signature]</u>	<u>7/12/16</u>	<u>1500</u>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@alglabsinc.com</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>SUNRISE</u>	Sampler: <u>Print Kelsey O'Connell Stephanie Dilbone</u> Sampler: Signature _____

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 6 Bathroom sink	DW/Grab	7-8	3:30	Lead	P	1			011A
Rm 6 sink	DW/Grab	7-8	3:31	Lead	P	1			012A
Rm 7 fountain	DW/Grab	7-8	3:25	Lead	P	1			013A
Rm 7 Bathroom sink	DW/Grab	7-8	3:25	Lead	P	1			014A
Rm 7 sink	DW/Grab	7-8	3:24	Lead	P	1			015A
Rm 8 fountain	DW/Grab	7-8	3:24	Lead	P	1			016A
Rm 8 BR sink	DW/Grab	7-8	3:23	Lead	P	1			017A
Rm 8 sink	DW/Grab	7-8	3:23	Lead	P	1			018A
Rm 9 Fountain	DW/Grab	7-8	3:21	Lead	P	1			019A
Rm 9 sink	DW/Grab	7-8	3:21	Lead	P	1			020A

Notes:

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: <u>ALG Carrier</u>	Refrigerated: <u>NA</u>
---	---------------------------------	-------------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
			<u>MF</u>	<u>7/12/16</u>	<u>1400</u>
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>MF</u>	<u>7/12/16</u>	<u>1500</u>	<u>[Signature]</u>	<u>7/12/16</u>	<u>1500</u>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering more than just test results.

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@alglabsinc.com</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Sunrise</u>	Sampler: <u>Print Kelsey O'Connell Stephanie Dilbone</u>
	Sampler: <u>Signature</u>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 13 Fountain	DW/Grab	7-8	3:56	Lead	P	1			021A
Rm 13 sink	DW/Grab	7-8	3:56	Lead	P	1			022A
Rm 14 sink	DW/Grab	7-8	3:51	Lead	P	1			023A
Rm 14 fountain	DW/Grab	7-8	3:51	Lead	P	1			024A
Rm 15 sink	DW/Grab	7-8	3:56	Lead	P	1			025A
Rm 16 sink	DW/Grab	7-8	3:49	Lead	P	1			026A
Rm 17 sink	DW/Grab	7-8	3:47	Lead	P	1			027A
Rm 17 ^{sink} fountain	DW/Grab	7-8	3:47	Lead	P	1			027A
Rm 18 sink	DW/Grab	7-8	3:54	Lead	P	1			028A
Rm 19 sink	DW/Grab	7-8	3:54	Lead	P	1			029A

Notes:
Rm 17 sink per bottle, confirmed w/ client 7/13/16 SKH

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> <u>NORMAL</u> <input type="checkbox"/> <u>RUSH</u>	Shipped Via: <u>ALG Courier</u>	Refrigerated: <u>NA</u>
--	---	-----------------------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
			<u>MF</u>	<u>7/12/16</u>	<u>1400</u>
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>MF</u>	<u>7/12/16</u>	<u>1500</u>	<u>[Signature]</u>	<u>7/12/16</u>	<u>1500</u>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@alglabsinc.com</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>SUNRISE</u>	Sampler: <u>Print Kelsey O'Connell Stephanie Dillbone</u>
	Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Rm 20 sink	DW/Grab	7-8	3:54	Lead	P	1			030A
Rm 21 sink	DW/Grab	7-8	3:54	Lead	P	1			031A
cafeteria fountain	DW/Grab	7-8		Lead	P	1			
Rm 3 hall fountain	DW/Grab	7-8	3:38	Lead	P	1			032A
Rm 14 hall fountain	DW/Grab	7-8	3:52	Lead	P	1			033A
North dishwashing sink	DW/Grab	7-8	4:02	Lead	P	1			034A
South dishwashing sink	DW/Grab	7-8	4:03	Lead	P	1			035A
hand washing sink	DW/Grab	7-8	4:04	Lead	P	1			036A
Rm 34 Br sink	DW/Grab	7-8	3:59	Lead	P	1			037A
First Aid Rm sink	DW/Grab	7-8	3:58	Lead	P	1			038A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG Courier</u>	Refrigerated <u>NA</u>			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
			<u>MF</u>	<u>7/12/16</u>	<u>1400</u>
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>MF</u>	<u>7/12/16</u>	<u>1500</u>	<u>JA</u>	<u>7/12/16</u>	<u>1500</u>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: <u>Doug Pigman</u>	Client: <u>Greater Albany Public Schools</u>
Phone: <u>541/967-4513</u>	Address: <u>3610 Grand Prairie</u>
Email: <u>doug.pigman@albanyschools.k12.or.us</u>	City, State, Zip: <u>Albany, OR 97322</u>
Client Project: <u>Sunrise</u>	Sampler: <u>Print Kelsey O'Connell Stephanie Dillbone</u> Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
Resource Rm fountain	DW/Grab	7-8	3:14	Lead	P	1			039A
Resource Rm sink	DW/Grab	7-8	3:14	Lead	P	1			040A
Staff Rm sink	DW/Grab	7-8	3:15	Lead	P	1			041A
Gym fountain	DW/Grab	7-8	3:44	Lead	P	1			042A
Rm 10 fountain	DW/Grab	7-8	3:19	Lead	P	1			043A
Rm 10 sink	DW/Grab	7-8	3:20	Lead	P	1			044A
Staff room hall fountain	DW/Grab	7-8	3:18	Lead	P	1			045A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG Courier</u>	Refrigerated <u>NA</u>
Relinquished by:	Received by:	Date Time
Relinquished by:	Received by:	Date Time
	<u>MF</u>	<u>7/12/16</u> <u>1400</u>
Relinquished by:	Received by Laboratory:	Date Time
<u>MF</u>	<u>[Signature]</u>	<u>7/12/16</u> <u>1500</u>