



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

September 22, 2016

Doug Pigman
Greater Albany Public Schools
3610 Grand Prairie
Albany, OR 97322
TEL: (541) 967-4513
FAX

RE: West Albany Initial Round 2

Order No.: 1609563

Dear Doug Pigman:

Analytical Laboratory Group received 37 sample(s) on 9/13/2016 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 1609563
Date: 9/22/2016

CLIENT: Greater Albany Public Schools
Project: West Albany Initial Round 2

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.



WO#: 1609563
CLIENT: Greater Albany Public Schools
Project: West Albany Initial Round 2
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609563-001 **Client Sample ID** A/E Hall Fntn **Collection Date:** 9/12/2016 1:11:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	KG

Lab ID: 1609563-002 **Client Sample ID** B4 Faucet 1 **Collection Date:** 9/12/2016 1:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0352	0.0200	0.00400	*	mg/L	9/21/2016 12:53:00 PM	KG

Lab ID: 1609563-003 **Client Sample ID** B4 Faucet 2 **Collection Date:** 9/12/2016 1:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0265	0.0200	0.00400	*	mg/L	9/21/2016 12:53:00 PM	KG

Lab ID: 1609563-004 **Client Sample ID** B4 Faucet 4 **Collection Date:** 9/12/2016 1:31:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0296	0.0200	0.00400	*	mg/L	9/21/2016 12:53:00 PM	KG

Lab ID: 1609563-005 **Client Sample ID** B4 Faucet 5 **Collection Date:** 9/12/2016 1:31:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0124	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-006 **Client Sample ID** B4 Faucet 6 **Collection Date:** 9/12/2016 1:32:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0165	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-007 **Client Sample ID** B4 Faucet 8 **Collection Date:** 9/12/2016 1:32:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0212	0.0200	0.00400	*	mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-008 **Client Sample ID** B4 Faucet 9 **Collection Date:** 9/12/2016 1:32:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0120	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



WO#: 1609563
CLIENT: Greater Albany Public Schools
Project: West Albany Initial Round 2
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609563-009 **Client Sample ID:** B4 Faucet 10 **Collection Date:** 9/12/2016 1:33:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0197	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-010 **Client Sample ID:** B4 Faucet 11 **Collection Date:** 9/12/2016 1:33:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0390	0.0200	0.00800	*	mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-011 **Client Sample ID:** B4 Faucet 12 **Collection Date:** 9/12/2016 1:34:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0582	0.0200	0.00800	*	mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-012 **Client Sample ID:** B4 Faucet 13 **Collection Date:** 9/12/2016 1:34:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0536	0.0200	0.00800	*	mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-013 **Client Sample ID:** B2 Faucet 3 **Collection Date:** 9/12/2016 1:19:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0116	0.0200	0.00200		mg/L	9/16/2016 2:06:00 PM	KG

Lab ID: 1609563-014 **Client Sample ID:** B2 Faucet 4 **Collection Date:** 9/12/2016 1:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00477	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-015 **Client Sample ID:** B2 Faucet 5 **Collection Date:** 9/12/2016 1:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00309	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



WO#: 1609563
CLIENT: Greater Albany Public Schools
Project: West Albany Initial Round 2
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609563-016 **Client Sample ID:** B2 Faucet 6 **Collection Date:** 9/12/2016 1:21:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00286	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-017 **Client Sample ID:** B2 Faucet 7 **Collection Date:** 9/12/2016 1:21:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-018 **Client Sample ID:** B5 Faucet 1 **Collection Date:** 9/12/2016 1:24:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00791	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-019 **Client Sample ID:** B5 Faucet 2 **Collection Date:** 9/12/2016 1:25:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00915	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-020 **Client Sample ID:** B5 Faucet 3 **Collection Date:** 9/12/2016 1:25:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00411	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-021 **Client Sample ID:** B5 Faucet 4 **Collection Date:** 9/12/2016 1:26:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00269	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-022 **Client Sample ID:** B5 Faucet 5 **Collection Date:** 9/12/2016 1:26:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00497	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-023 **Client Sample ID:** B5 Faucet 6 **Collection Date:** 9/12/2016 1:27:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1609563
CLIENT: Greater Albany Public Schools
Project: West Albany Initial Round 2
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609563-024 **Client Sample ID:** B1 Faucet 1 **Collection Date:** 9/12/2016 1:18:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0146	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-025 **Client Sample ID:** B1 Faucet 2 **Collection Date:** 9/12/2016 1:18:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00818	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-026 **Client Sample ID:** B1 Faucet 3 **Collection Date:** 9/12/2016 1:19:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00646	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-027 **Client Sample ID:** B1 Faucet 4 **Collection Date:** 9/12/2016 1:19:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0118	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-028 **Client Sample ID:** B3 Faucet 1 **Collection Date:** 9/12/2016 1:27:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00559	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-029 **Client Sample ID:** B3 Faucet 2 **Collection Date:** 9/12/2016 1:28:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00514	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-030 **Client Sample ID:** B3 Faucet 3 **Collection Date:** 9/12/2016 1:28:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00955	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1609563
CLIENT: Greater Albany Public Schools
Project: West Albany Initial Round 2
PWS Number:
Sample Source:

Received Date: 9/13/2016 4:01:00 PM
Sampler Name: Jessica Dilbone
Matrix: Drinking Water
Sample Type:

Lab ID: 1609563-031 **Client Sample ID:** B3 Faucet 4 **Collection Date:** 9/12/2016 1:29:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0154	0.0200	0.00400		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-032 **Client Sample ID:** D6 Faucet 1 **Collection Date:** 9/12/2016 1:13:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0159	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-033 **Client Sample ID:** D6 Faucet 2 **Collection Date:** 9/12/2016 1:13:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0212	0.0200	0.00400	*	mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-034 **Client Sample ID:** E2 Faucet 1 **Collection Date:** 9/12/2016 1:44:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0430	0.0200	0.00800	*	mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-035 **Client Sample ID:** E2 Faucet 3 **Collection Date:** 9/12/2016 1:44:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0145	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-036 **Client Sample ID:** E2 Faucet 4 **Collection Date:** 9/12/2016 1:45:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0162	0.0200	0.00200		mg/L	9/21/2016 12:53:00 PM	PG

Lab ID: 1609563-037 **Client Sample ID:** E2 Faucet 5 **Collection Date:** 9/12/2016 1:45:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0398	0.0200	0.00800	*	mg/L	9/21/2016 12:53:00 PM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1609563
 22-Sep-16

Client: Greater Albany Public Schools
Project: West Albany Initial Round 2

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1609563-001A	A/E Hall Fntn	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1609563-002A	B4 Faucet 1			Lead	A
	1609563-003A	B4 Faucet 2			Lead	A
	1609563-004A	B4 Faucet 4			Lead	A
	1609563-005A	B4 Faucet 5			Lead	A
	1609563-006A	B4 Faucet 6			Lead	A
	1609563-007A	B4 Faucet 8			Lead	A
	1609563-008A	B4 Faucet 9			Lead	A
	1609563-009A	B4 Faucet 10			Lead	A
	1609563-010A	B4 Faucet 11			Lead	A
	1609563-011A	B4 Faucet 12			Lead	A
	1609563-012A	B4 Faucet 13			Lead	A
	1609563-013A	B2 Faucet 3			Lead	A
	1609563-014A	B2 Faucet 4			Lead	A
	1609563-015A	B2 Faucet 5			Lead	A
	1609563-016A	B2 Faucet 6			Lead	A
	1609563-017A	B2 Faucet 7			Lead	A
	1609563-018A	B5 Faucet 1			Lead	A
	1609563-019A	B5 Faucet 2			Lead	A
	1609563-020A	B5 Faucet 3			Lead	A
	1609563-021A	B5 Faucet 4			Lead	A
	1609563-022A	B5 Faucet 5			Lead	A
	1609563-023A	B5 Faucet 6			Lead	A
	1609563-024A	B1 Faucet 1			Lead	A
	1609563-025A	B1 Faucet 2			Lead	A
	1609563-026A	B1 Faucet 3			Lead	A
	1609563-027A	B1 Faucet 4			Lead	A
	1609563-028A	B3 Faucet 1			Lead	A
	1609563-029A	B3 Faucet 2			Lead	A
	1609563-030A	B3 Faucet 3			Lead	A
	1609563-031A	B3 Faucet 4			Lead	A

ORELAP A Accredited

ACCRED



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

**Accreditation Program
 Analytes Report**
 WO#: 1609563
 22-Sep-16

Client: Greater Albany Public Schools
Project: West Albany Initial Round 2

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1609563-032A	D6 Faucet 1	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1609563-033A	D6 Faucet 2			Lead	A
	1609563-034A	E2 Faucet 1			Lead	A
	1609563-035A	E2 Faucet 3			Lead	A
	1609563-036A	E2 Faucet 4			Lead	A
	1609563-037A	E2 Faucet 5			Lead	A

ORELAP A Accredited

ACCRED



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1609563

Date: 9/22/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1609563

Date: 9/22/2016

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Deliver just fast



CHAIN OF CUSTODY

Attention: Doug Pigman	Client: Greater Albany Public Schools	
Phone: 541-967-4513	Address: 3610 Grand Prairie	
Email: doug.pigman@albany.k12.or.us	City, State, Zip: Albany, OR 97322	
Client Project: West Albany Initial Round 2	Sampler: Print Jessica Dillbone	Sampler: Signature Jessica Dillbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
A/E Hall Fountain	DW/Grab	9-12-16	1:11a	Lead	P	1			001A
B4 Faucet 1	DW/Grab	9-12	1:30a	Lead	P	1			002A
B4 Faucet 2	DW/Grab	9-12	1:30a	Lead	P	1			003A
B4 Faucet 4	DW/Grab	9-12	1:31a	Lead	P	1			004A
B4 Faucet 5	DW/Grab	9-12	1:31a	Lead	P	1			005A
B4 Faucet 6	DW/Grab	9-12	1:32a	Lead	P	1			006A
	DW/Grab			Lead	P	1			
B4 Faucet 8	DW/Grab	9-12	1:32a	Lead	P	1			007A
B4 Faucet 9	DW/Grab	9-12	1:32a	Lead	P	1			008A
B4 Faucet 10	DW/Grab	9-12	1:33a	Lead	P	1			009A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG Courier	Refrigerated NA
--	------------------------------------	---------------------------

Relinquished by: Jessica Dillbone	Date 9-13-16	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory: <i>[Signature]</i>	Date 9/13/16	Time 1601

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results.

CHAIN OF CUSTODY

Attention: Doug Pigman	Client: Greater Albany Public Schools
Phone: 541-967-4513	Address: 3610 Grand Prairie
Email: doug.pigman@albany.k12.or.us	City, State, Zip: Albany, OR 97322
Client Project: West Albany Initial Round 2	Sampler: Print Jessica Dilbone
	Sampler: Signature Jessica Dilbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
B4 Faucet 11	DW/Grab	9-12-16	1:33a	Lead	P	1			010A
B4 Faucet 12	DW/Grab	9-12	1:34a	Lead	P	1			011A
B4 Faucet 13	DW/Grab	9-12	1:34a	Lead	P	1			012A
 	DW/Grab	 	 	Lead	P	1	 	 	
 	DW/Grab	 	 	Lead	P	1	 	 	
B2 Faucet 3	DW/Grab	9-12	1:19a	Lead	P	1			013A
B2 Faucet 4	DW/Grab	9-12	1:20a	Lead	P	1			014A
B2 Faucet 5	DW/Grab	9-12	1:20a	Lead	P	1			015A
B2 Faucet 6	DW/Grab	9-12	1:21a	Lead	P	1			016A
B2 Faucet 7	DW/Grab	9-12	1:21a	Lead	P	1			017A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
<input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	ALG Courier	NA

Relinquished by: Jessica Dilbone	Date 9-13-16	Time 	Received by: 	Date 	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory: <i>[Signature]</i>	Date 9/13/16	Time 1601

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: Doug Pigman	Client: Greater Albany Public Schools	
Phone: 541-967-4513	Address: 3610 Grand Prairie	
Email: doug.pigman@albany.k12.or.us	City, State, Zip: Albany, OR 97322	
Client Project: West Albany Initial Round 2	Sampler: Print Jessica Dillbone	Sampler: Signature Jessica Dillbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
B5 Faucet 1	DW/Grab	9-12-16	1:24a	Lead	P	1			018A
B5 Faucet 2	DW/Grab	9-12	1:25a	Lead	P	1			019A
B5 Faucet 3	DW/Grab	9-12	1:25a	Lead	P	1			020A
B5 Faucet 4	DW/Grab	9-12	1:26a	Lead	P	1			021A
B5 Faucet 5	DW/Grab	9-12	1:26a	Lead	P	1			022A
B5 Faucet 6	DW/Grab	9-12	1:27a	Lead	P	1			023A
B1 Faucet 1	DW/Grab	9-12	1:18a	Lead	P	1			024A
B1 Faucet 2	DW/Grab	9-12	1:18a	Lead	P	1			025A
B1 Faucet 3	DW/Grab	9-12	1:19a	Lead	P	1			026A
B1 Faucet 4	DW/Grab	9-12	1:19a	Lead	P	1			027A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG Courier	Refrigerated NA
--	------------------------------------	---------------------------

Relinquished by: Jessica Dillbone	Date 9-13-16	Time 	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory: 	Date 9/13/16	Time 1601

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results.

CHAIN OF CUSTODY

Attention: Doug Pigman	Client: Greater Albany Public Schools	
Phone: 541-967-4513	Address: 3610 Grand Prairie	
Email: doug.pigman@albany.k12.or.us	City, State, Zip	Albany, OR 97322
Client Project: West Albany Initial Round 2	Sampler: Print Jessica Dillbone	Sampler: Signature Jessica Dillbone

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
B3 Faucet 1	DW/Grab	9-12-16	1:27a	Lead	P	1			028A
B3 Faucet 2	DW/Grab	9-12	1:28a	Lead	P	1			029A
B3 Faucet 3	DW/Grab	9-12	1:28a	Lead	P	1			030A
B3 Faucet 4	DW/Grab	9-12	1:29a	Lead	P	1			031A
D6 Faucet 1	DW/Grab	9-12	1:13a	Lead	P	1			032A
D6 Faucet 2	DW/Grab	9-12	1:13a	Lead	P	1			033A
E2 Faucet 1	DW/Grab	9-12	1:44a	Lead	P	1			034A
E2 Faucet 3	DW/Grab	9-12	1:44a	Lead	P	1			035A
E2 Faucet 4	DW/Grab	9-12	1:45a	Lead	P	1			036A
E2 Faucet 5	DW/Grab	9-12	1:45a	Lead	P	1			037A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG Courier	Refrigerated NA
--	------------------------------------	---------------------------

Relinquished by: Jessica Dillbone	Date 9-13-16	Time _____	Received by: _____	Date _____	Time _____
Relinquished by: _____	Date _____	Time _____	Received by: _____	Date _____	Time _____
Relinquished by: _____	Date _____	Time _____	Received by Laboratory: _____	Date 9/13/16	Time 1601