

Radon test result report for:
FAIRMOUNT SCHOOL
 N/A

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7856442	1	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856433	14	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856434	14	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856441	15	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856435	16	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856448	17	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856437	2	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856432	21	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856445	3	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856438	4	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	0.6 ± 0.3	2017-11-21
7856439	5	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856447	7	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	1.1 ± 0.3	2017-11-21
7856443	9	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856444	9	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856440	GYM	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	12.7 ± 1.2	2017-11-21
7856430	GYM	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856446	GYM	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856436	OFFICE	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856431	OFFICE	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21