

Radon test result report for:

**FIR GROVE ELEMENTARY SCHOOL**

N/A

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7856460	1	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856450	2	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856451	3	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856452	4	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856449	5	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856462	5	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856459	7	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856458	7	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856455	8	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856456	8	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856454	CAF	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856464	GYM	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856463	GYM	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856453	LIB	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21
7856457	LIB	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	12.6 ± 1.2	2017-11-21
7856461	SPEECH	2017-11-14 @ 7:00 am	2017-11-17 @ 9:00 am	< 0.3	2017-11-21