

Radon test result report for:**NORTH ALBANY ELEMENTARY SCHOOL****N/A**

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7856752	1	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856741	10	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856734	12	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856753	13	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856750	14	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856733	2	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856746	2	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856737	3	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856742	4	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856740	5	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856747	6	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	0.8 ± 0.3	2017-11-21
7856748	7	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	1.4 ± 0.4	2017-11-21
7856731	8	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856739	8	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	0.6 ± 0.3	2017-11-21
7856743	9	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856732	9	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856735	GYM	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	9.9 ± 1.0	2017-11-21
7856754	GYM	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856749	GYM	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	0.6 ± 0.3	2017-11-21
7856736	LIB	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856744	LIB	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856745	OFFICE	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21
7856751	STAGE	2017-11-14 @ 7:00 am	2017-11-17 @ 7:00 am	< 0.3	2017-11-21