

Radon test result report for:
TIMBER RIDGE SCHOOL
 N/A

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7856206	A100	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856255	A101	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856251	A101	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856252	A102	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856208	A103	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856227	A104	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856257	A104	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856207	A105	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856256	A106	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856221	A107	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856201	A107	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856203	A108	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856204	A109	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856205	A110	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856225	A111	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856210	B100	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856209	B100	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856240	B101	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856218	B102	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856217	B103	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856237	B104	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856222	B105	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856216	B106	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856228	B106	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	0.6 ± 0.4	2017-11-14
7856215	B107	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856214	B108	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856230	B109	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	0.8 ± 0.4	2017-11-14
7856239	B110	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856226	B111	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	0.8 ± 0.4	2017-11-14
7856219	B112	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856220	B112	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856244	CAF	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856245	CAF	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856247	CAF	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856238	GYM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856233	GYM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856234	GYM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14

Radon test result report for:
TIMBER RIDGE SCHOOL
 N/A

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7856223	GYM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	16.5 ± 1.7	2017-11-14
7856235	GYM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856213	GYM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856249	HALL A FOCUS RM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856254	LIBRARY	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	15.8 ± 1.7	2017-11-14
7856253	MEDIA CENTER	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	???? UI	2017-11-14
7856211	MEDIA ROOM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	???? UI	2017-11-14
7856231	MEDIA ROOM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856232	MEDIA ROOM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856212	MUSIC ROOM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856236	MUSIC ROOM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856250	OFFICE	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856202	OFFICE	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856243	S GYM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856241	S GYM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856242	S GYM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856224	SMALL CONF ROOM	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856246	STAGE	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14
7856248	STAGE	2017-11-05 @ 1:00 pm	2017-11-09 @ 6:00 am	< 0.3	2017-11-14