

Central Elementary School Test Kit Log and Test Results

<u>Serial Number</u>	<u>Start Date</u>	<u>Start Time</u>	<u>Stop Date</u>	<u>Stop Time</u>	<u>Temp.</u>	<u>Facility</u>	<u>Building</u>	<u>Room</u>	<u>Proj. ID</u>	<u>Floor</u>	<u>Test Results</u>
7856258	12/05/2017	5:30 AM	12/08/2017	5:25 AM	68F - 74F	Central Elementary School	N/A	Basement Café	Rad	0	0.6 ± 0.3
7856259	12/05/2017	5:30 AM	12/08/2017	5:25 AM	68F - 74F	Central Elementary School	N/A	14	Rad	0	<0.3
7856260	12/05/2017	5:30 AM	12/08/2017	5:25 AM	68F - 74F	Central Elementary School	N/A	Behavior Room	Rad	0	lost
7856261	12/05/2017	5:30 AM	12/08/2017	5:25 AM	68F - 74F	Central Elementary School	N/A	14	Rad	0	0.6 ± 0.3
7856263	12/05/2017	5:30 AM	12/08/2017	5:25 AM	68F - 74F	Central Elementary School	N/A	12	Rad	0	0.8 ± 0.3
7856264	12/05/2017	5:30 AM	12/08/2017	5:25 AM	68F - 74F	Central Elementary School	N/A	Kitchen	Rad	0	<0.3
7856265	12/05/2017	5:30 AM	12/08/2017	5:25 AM	68F - 74F	Central Elementary School	N/A	Café	Rad	0	0.6 ± 0.3
7856266	12/05/2017	5:30 AM	12/08/2017	5:25 AM	68F - 74F	Central Elementary School	N/A	Café	Rad	0	<0.3
7856267	12/05/2017	5:30 AM	12/08/2017	5:25 AM	68F - 74F	Central Elementary School	N/A	Kitchen	Rad	0	<0.3